



## ADDITIONAL INFORMATION

## INDEX

S.No.	Description	Page Number
1	Maintenance Policy	1-6
2	Annual Maintenance Contract	7-31
3	Departments Lab Maintenance Register	32-68
4	Calibration of Equipments	69-94
5	House Keeping Maintenance	95-107
6	Printers, Scanners & copiers Maintenance	108-111
7	RO Plant Maintenance	112-144
8	Electrical Maintenance (AC, Battery, UPS etc.)	145-152
9	Library Maintenance	153-173
10	Sewage Treatment Plant Maintenance	174-180

### PRINCIPAL

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.





## MAINTENANCE POLICY

PSN College of Engineering and Technology strives to maintain the Academic and Physical facilities for the better utilization of the resources and to minimize depreciation.

The college is having an estate office for maintenance of physical facility which is headed by the estate officer. Systematic procedures have been developed for maintaining the academic facilities. Respective heads of various departments/divisions like HoDs of departments, librarian, and physical director are taking care of maintenance of academic facilities.

In addition to the available maintenance team of the college, the college has also signed agreement for maintenance of fire fighting system, lift, computers, CCTV camera, ERP software, air conditioners etc. Transport Department is headed by its Manager. The maintenance works of all buses, Cars, Vans, Mini Trucks, Tractors, Bulldozer, Electric cars are taken care of by Transport Department. Sewage treatment plant of the college is run and maintained by a team of technicians. The paper waste collected from departments are sent to the waste paper recycling plant which is run inside the college campus under the control of Mechanical and Automation Engineering Department.

Housekeeping team of the college is taking care of all indoor and outdoor sweeping in and around academic buildings, hostels, administrative buildings and library. As large number of trees and plantations are being maintained by the college to make the campus green, the dead leaves collected from the plants during sweeping is used for making bio compost. Use of polythene bags and plastics is banned inside the campus. The food waste collected from the mess is sent to pig farm.

The college follows systematic procedures in maintaining and utilizing the equipment.

### **1. Laboratory**

#### **(a) Maintenance of Laboratory**

- Stock Register is maintained in all departments/Divisions.
- Trained lab Technicians are available in laboratories.

**PSNCET, Tirunelveli**



**PRINCIPAL**  
**PSN COLLEGE OF ENGINEERING & TECHNOLOGY**  
**MELATHEDIYOR, PALAYAMKOTTAI TALUK**  
**TIRUNELVELI DIST. - 627 152.**



- Internal stock verification is done every year by a committee constituted by the Principal. Follow up action is taken on the committee's recommendations.
- Labs are painted and upkeep of materials is done regularly.
- Fire extinguishers are installed and refilling is done periodically.
- Instruments and equipment are serviced regularly and as and when required.
- Instruments are periodically calibrated.


#### (b) Utilization of Laboratory

- Theory papers are suitably supplemented with practical components
- Faculty and scholars carry out their research
- Lab timetables are prepared and followed in discussion with overall co-ordinator.
- Laboratories are kept open beyond the working hours.
- Utilization register is maintained in all laboratories and facilities.

### 2. College Library

#### (a) Maintenance of College Library

- Classification of stacks for Science, Humanities, Engineering and Management, reference and competitive examinations.
- Carrying out extensive annual and internal stock verification
- OPAC facility to access and verify availability of books
- Marking books with unique accession number and arranging in respective subject racks
- Monitoring attendance of library users through e-gate entry
- Displaying 'new arrivals' in separate rack
- Placing Ph.D. thesis in a separate rack in the reference section.
- Adequate number of fire extinguishers placed in the appropriate locations.
- A separate binding section is functioning for maintaining of books and other materials



**PRINCIPAL**

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
VELATHEDIYOD, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.



## (b) Utilization of Library

- Library functions 24 × 7
- Display the useful newspaper clippings about the college, career opportunities, awards, scholarships, research grants at the entrance of the library.
- Digital library is available for users to download E-books and E-journals using INFLIBNET, DELNET, J – Gate, British Council, Taylor & Francis, IEE and Elsevier.
- A separate reading room is provided with books and periodicals for the aspirants of competitive examinations.
- Braille materials are available for visually-challenged students.
- URKUND plagiarism software is used by staff and research scholars through Research supervisor's login.
- Research scholars and students of neighbouring colleges use the library for reference
- Photocopying and scanning facilities are provided to all users.

## 3. Sports Facilities

### (a) Maintenance of Sports Complex

All Sports facilities like play fields, courts, tracks, flood lights, gym, indoor stadium, and swimmingpool etc. are properly maintained regularly with the help of skilled labours and markers. All the sports infrastructure, its stock and maintenance are done under the headship of Physical Director of the college. Two physical instructors and two markers are assisting the Physical Director.

1. 400 m tracks and fields are watered and rolled once in a week.
2. Kabaddi and Volleyball Court are watered and markings are done daily. Also the Wood dust Powders are sprinkled on the Ground Surface.
3. Basketball court is cleaned every day and painted every year.
4. Hockey and Football fields are cleaned, watered and rolled once in a week.
5. Swimming pool is maintained with water purification and water top up is done if required.

**PSNCET, Tirunelveli**



**PRINCIPAL**

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOD, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.



6. Gym equipment are cleaned and lubricated every day.
7. Indoor sports facilities are maintained every day.

#### b) Utilization

1. All girl and boy students are encouraged to involve themselves at least in a one game.
2. Boys and girls are given separate play fields and courts for their practice session.
3. Identified sports players and students admitted under sports quota are given regular training in the morning (6 to 7.45am) and evening (5.15pm to 7pm)
4. In Yoga centre, meditation and yoga classes are conducted regularly in the morning and evening respectively.
5. Swimming practice is given to all students by a trained coach on holidays and in the evening time.
6. Gym is open to all dayscholar and hostel students during morning and evening and on holidays.
7. Training on athletics is given to the students in the morning and evening every day. Specific athletic training is also given.
8. TA and DA are given to the students and accompanying physical education department staff for participating in the state, national level and university matches.
9. National level PSN trophy for men and women is conducted every year in the month of February for four games viz. Volleyball, Kabaddi, Basketball and hockey.
10. Physical training and parade are conducted in the morning of everyday for B.E- Marine Engineering students as per the Director General of shipping (DGS) norms by a parade officer designated for this purpose.
11. Health and nutrition classes are conducted regularly to all students.

#### 4. Computer

##### (a) Maintenance of Computer

1. Computer support group headed by a faculty of computer science and engineering takes care of maintenance of computers, printers, networking switches, LAN and internet.

PSNCET, Tirunelveli





2. It also ensures the proper working of all installed softwares and reinstall the software or upgrade it as and when required.
3. Old computers with very low configurations are upgraded by changing the hardware. Also, they are replaced by high end computers.
4. All academic, administrative and hostel buildings are connected by optical fibre cable for high-speed intranet/internet access.
5. SonicWall firewall is used for security and user management.
6. System files cleaning and fragmentation is done periodically.
7. Fire extinguishers are placed in appropriate location and refilled periodically by a company with which AMC agreement has been signed.
8. Softwares are being purchased with three-year AMC agreement for version upgrade and maintenance.
9. Proper power backup is provided to all computers with online ups end generator set.

#### (b) Utilization of computer

1. Timetable is prepared for all practical courses without any clash.
2. Online tests (MCQ), Quizzes and assignments are conducted.
3. Students are encouraged to learn the subjects in NPTEL & SWAYAM.
4. Computer laboratories are open beyond the working hours for students and research scholars use.
5. Students use the computers systems to download and read E-Journals and Resources.

#### 5. Classrooms

The ICT tools and smart boards available in the classrooms are maintained by the computer support group (CSG) of the college. Estate office is taking care of civil, electrical maintenance and housekeeping of classrooms.

Academic building and classrooms and seminar halls are properly illuminated and 90% of the tube lights have been replaced by energy saving LED lights. Energy saving instructions/posters are placed in all rooms and corridors with the aim of saving energy. Academic buildings have power backup with UPS/Genset.

PSNCET, Tirunelveli\*



  
**PRINCIPAL**  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.



# PSN College of Engineering and Technology

An Autonomous Institution, Affiliated to Anna University

Approved by AICTE, Accredited by NAAC with A+ Grade

## (a) Utilization of Classrooms

- After the regular academic hours, classrooms are used for value added courses, competitions, association meetings, competitive exam trainings etc.

## 6. Other Support Facilities

ATM, Photostat centre, Canteen, Children's day care centre, Dispensary, Stores are well maintained by the concerned in-charges and the Estate office.



✓  
✓

PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIVODR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.

PSNCET, Tirunelveli



**NON COMPREHENSIVE ANNUAL MAINTENANCE CONTRACT  
FOR YOUR CUMMINS DG SET**

Ref: JNMPL/AMC/RENEWAL/570/20-21

Date: 15.12.2020

To:

**M/s. PSN COLLEGE OF ENGINEERING AND TECHNOLOGY  
MELATHIDIYOR POST  
PALAYAMKOTTAI TALUK, TIRUNELVELI**

This contract is entered into between JN MACHINERIES PRIVATE LIMITED, hereinafter referred to as the 'JNMPL' which expression unless repugnant to the context or meaning thereof shall mean and include its successors and M/s. PSN COLLEGE OF ENGINEERING AND TECHNOLOGY, assigns and hereinafter referred to as 'CUSTOMER' which expression unless repugnant to the context or meaning thereof shall mean and include its successors and assigns.

Whereas the 'JNMPL' is engaged in the business of providing after sales service to Cummins Engines and parts thereof and Diesel Generating sets fitted with Cummins Engines.

Whereas the 'CUSTOMER' is the owner of Diesel generating set fitted with Cummins Engine

Whereas the 'CUSTOMER' has requested to the 'JNMPL' to provide after sales service to the DG Set powered with Cummins products owned by the 'CUSTOMER' & installed at 'CUSTOMER' Premises/ plant/ factory as per the Price Schedule "A"

Now therefore this contract is entered into between the 'JNMPL' and 'CUSTOMER' on the following terms and conditions

**DEFINITIONS:**

"D.G. Set" means Diesel Generating set fitted with Cummins Engine & Main Alternator and its control panels.

"Day" Means eight hours or part thereof.

**MAINTENANCE OF RECORD:**

All record for maintenance, failure and corrective actions taken, shall be jointly kept by both 'PSN CEC' and the 'JNMPL'.



JN Machineries Private Limited  
Authorized Cummins Dealer  
Tirunelveli Office  
No. 7/1 Kurnachi Nagar Main Road  
Opp. KTC Nagar, VM Chavram  
Tirunelveli - 627 011  
Phone +91 462 2520006 2520884  
Email: jnmpl@jnmpl.com

Registered Office  
Nathan Road, Maran Vilakku,  
Oonachikulam, Madurai-625 014, TEL: 0452 2681765 - 2680001  
Phone +91 452 2681765 - 2680001  
Fax +91 452 2681515  
Email: jnmdu@jnmpl.com

**PRINCIPAL**  
**PSN COLLEGE OF ENGINEERING & TECHNOLOGY**  
**MELATHIDIYOR, PALAYAMKOTTAI TALUK**  
**TIRUNELVELI DISTRICT - 627 152**



1. During the service contract period, it should be obligatory that no other person other than JNMPL representative or 'CUSTOMER's authorized staff should open the engine to carry out any repair. It would also be obligatory that the 'CUSTOMER' shall purchase parts from Cummins authorized sources and repair and job work is done from an authorized service center of Cummins. If in case, it is observed that the parts have been purchased from unauthorized source or service has been taken from an unauthorized person, JNMPL shall not be responsible for any of the obligations under this Contract and shall have the right to terminate the Contract forthwith.
2. Lock out and tag out procedures to be incorporated adheres to the safety standards.
3. In no event shall the JNMPL be held responsible for any consequences whether direct or indirect which may arise out of 'CUSTOMER's non compliance to the afore mentioned obligations in this clause.
4. JSL would be responsible for insuring its assets and JNMPL would not be responsible for theft or fire or acts of God, loss or accidental damage to the equipment.

#### PAYMENT TERMS:

Within 30 days after submission of invoices or otherwise as agreed between JNMPL & 'CUSTOMER'

#### VALIDITY:

This contract will be in effect from JAN'21 to DEC'21 and AMC contract will be getting expired subject to the contract period or completion of 4 Visits whichever occurs earlier. The AMC shall start on the date of signing the AMC and will be valid for a period of 1 year, unless terminated earlier by the parties. (As per the termination guidelines)

#### TERMINATION:

Either party may terminate this contract by giving written notice of not less than 30 days. In case of termination the service provider will refund the advance payment made for the services not availed by the 'CUSTOMER' on prorate basis less Service Tax & any other taxes paid by Service provided. This contract shall become null and void if above DG set is shifted from original location to elsewhere without consent of the JNMPL.  
In case during the period of maintenance agreement, the DG is relocated (or) transported without sufficient prior intimation to the JNMPL, the provider reserves the right to terminate this agreement forthwith. On such termination, 'CUSTOMER' shall have no obligation or liabilities arising out of this agreement and the 'CUSTOMER' shall have no right to claim any refund or compensation.



JN Machines Private Limited  
Authorized Cummins Dealer  
Tirunelveli Office  
No: T-1, Kanchi Nagar Main Road  
Opp. KTC Nagar, VM Chatham  
Tirunelveli - 627 011  
Phone +91 452 2520006-2520884

  
**PRINCIPAL**  
**PSN COLLEGE OF ENGINEERING & TECHNOLOGY**  
**MELATHEDIYOD, PALAYAMKOTTAI TALUK**

Registered Office  
Nathan Road, Maran Vilakku  
Oomachikulam, Madurai-625 014  
Phone +91 452 2681765, 2680001  
Fax +91 452 2681515



#### LIMITATION OF LIABILITY:

Notwithstanding anything mentioned in this Contract or in any document processed referring this Contract, the total liability of JNMPL shall be limited upto the amount received by JNMPL till the date. Neither Party shall in any event be liable for any special, indirect, consequential, or incidental damages arising in any way out of this Contract.

#### FORCE MAJEURE

Neither party will be held liable for delays or other failure to perform its obligations which are due to any factor or event outside its reasonable control. Such factors or events dispute, civil commotion, fire or other accident, governmental act or regulation, embargo, not, armed conflict, war, terrorism (Including any threat of not, armed conflict, war and terrorism),act of God, Court order, inclement weather, natural catastrophe, epidemic, respondent non-cooperation, virus/hacker attack, delay or interruption in public communication service, and utility outage.

#### ARBITRATION

Any dispute or difference whatsoever between and parties or person or persons claiming through them arising out of or connection with this contract or regarding the rights or liabilities of the parties or regarding interpretation of this contract or any clause thereof including interpretation of this clause shall be referred to arbitration of two arbitrators, One to be appointed by the Contractor and other by the 'CUSTOMER' and proceedings of the Arbitration Act, 1996 and any statutory modification or re-enactment thereof. Only competent courts at Chennai shall have jurisdiction over the arbitration proceedings in respect of the matters require to be dealt with the Courts in accordance with the Indian Arbitration Act, 1996 except the courts exercising jurisdiction under the Arbitration act as above. No other Court, Tribunal, Commission or Forum (including Consumer Forum, Commission OR Tribunal) shall have any jurisdiction over any dispute and that such jurisdiction is hereby specifically excluded.)

#### GOVERNING LAWS AND JURISDICTION

This Contract shall be governed and construed according to the laws of India. All judicial proceedings shall be subject to the jurisdiction of MADURAI ( India).

This Contract is entered on this.....

Dealership

For JN MACHINERIES PVT LTD

AUTHORIZED SIGNATORY

For PSN COLLEGE OF ENGINEERING AND TECHNOLOGY

AUTHORIZED SIGNATORY



JN Machineries Private Limited  
Authorized Cummins Dealer  
Tirunelveli Office  
No. 7/1 Karmachi Nagar Main Road  
Opp. KTC Nagar VM Chavaram  
Tirunelveli - 627 011  
Phone +91 462 2520006, 2520684  
Email: jnmpl@jnmpl.com

Registered Office  
Nathan Road, Maran Vilakku  
Oonachikulam, Madurai-625 014  
Phone +91 452 2681765, 2680001  
Fax +91 452 2661515  
Email: jnmdu@jnmpl.com

PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIVOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST - 627 152

**FIELD SERVICE REPORT  
THREE PHASE UPS**

Doc #: CONSUL-FOR-SER-016  
Rev #: 01(25-Sep-19)  
Page #: 1 Of 1

Service Request No:  
1100705763

Order No:  
6000663417

Call Received On & Time:  
05-SEP-2019 12:48

Contact Person: MR.JEGANLAL

Contact Number: 04634- 279680/978921

Mail Id: IDZTIRUNELVELI@PSNCET.AC.IN

Web Site:

Warranty Period: FROM 15-SEP-2016 TO 14-SEP-2021

Model	MU3K	Sub Model:	Serial Number:	Capacity:	Unit Status:
UPS	FALCON 8K		000020161900060267	135 KVA	WARRANTY
Battery Make	AH	Model:	Battery Bank:	Quantity:	Batch code:
EXIDE	150	SMF	2	32	4UK - 32F

Call category:

BATTERY REPLACEMENT

Customer Complaint:

BATTERY REPLACEMENT

Call Status:

COMPLETED

Customer Diagnosis / Observation: BATTERY REPLACEMENT

Actual Action: 32 NO'S OF 150AH EXIDE NXT BATTERIES HAS REPLACED, NOW UPS IS WORKING FINE AND ALL BATTERIES ARE GOOD CHARGING CONDITION, ALL PARAMETERS ARE GOOD FUNCTIONING

Customer suggestion if any:

Customer Repairs if Any:

Customer Failed to Replace if Any:

IP Volts	IP Current	Radiifer DC Volts	Battery	OPV Volts	OP Current	Frequency	Temperature
RV RV BN NE RA YA BA PN +VSE -VSE Volt	Amps	UN VN WN UA VA WA IP OP Amb HS					
234 234 237 1 15 12 13 432 - - 450 6 230 230 230 4 3 5 49.9 49.9 28 34							

Customer Equipment Details: COMPUTER

Customer Photo:

Engineer Signature:

Engineer Name:  
NAGAMUTHUP

Customer Details to have been given:  
Customer Name: Our Satisfaction We  
Customer Address: Changes for the same will  
Customer Contact No:

Call Attended Date Time:

05-SEP-2019 13:00

Unit Working Status:

WORKING OK

05-SEP-2019 18:01

Call completed Date Time:

05-SEP-2019 18:52

Customer Photo:

Customer Sign:

Unit Serial Number:

Display:


Site:

NO:  
IMAGE:

05-SEP-2019 18:06



05-SEP-2019 17:59



05-SEP-2019 17:59



05-SEP-2019 18:00

Customer Address: 401 KAMALAM BUILDING NO.7, FIRST FLOOR, NEW LIG COLONY, ANNA NAGAR, MADURAI - 625 020

Customer City: CONSUL NEOWATT POWER SOLUTIONS PVT LTD, 119, Electrical & Electronics Industrial Estate, Perungudi, Chennai - 600036

Customer Contact No: 0-761000 9955

Email: support@consulneowatt.com

Web: www.consulneowatt.com

**PRODUCTS OFFERING**

Three Phase Online UPS / Enterprise Class Online UPS / Industrial Systems / DC Power Systems / Static Transfer Switch / Active Harmonic Filter / Solar Inverter / ESS / Power Banks / Industrial Inverters / Stabilizers / Energy Conserver For Lighting / Isolation Transformers / Ultra Isolation Transformers / K Rated Transformers

**SERVICES OFFERING**

Annual Preventive Maintenance Contracts / CAVC / Annual Maintenance Contracts ( Labour - AMC ) / AMC for Third Party Stabilizers / Battery Replacement in Zones / Power Audit / Nonlinear Loads / Rental UPS And Stabilizers / Stabilizer Oil Replacement / Remote Monitoring

**PRINCIPAL**  
**PSNCET COLLEGE OF ENGINEERING & TECHNOLOGY**  
**MELATHEDIYOD, PALAYAMKOTTAI TALUK**  
**TIRUNELVELI DIST - 627 152**



# **ANAX INFOTECH Pvt. Ltd.,**


## **CCTV Annual Maintenance Contract**

**Date: 01.11.2016**

### **Services**

ANAX INFOTECH Pvt. Ltd., CCTV Annual Maintenance Contract provides the following services:

<b>Criteria</b>	<b>Description</b>
<b>ANAX INFOTECH Pvt. Ltd., Annual Maintenance</b>	ANAX INFOTECH Pvt. Ltd., carries maintenance Activities according to Equipment specific maintenance schedule for each equipment.
<b>ANAX INFOTECH Pvt. Ltd., Customer Support Team</b>	ANAX INFOTECH Pvt. Ltd., Customer Support handle technical failures and faults in the CCTV Cameras or for requests of other assistance on site. ANAX INFOTECH Pvt. Ltd., Customer Support Team can be easily accessed through one IVR number and through support portal as tickets <b>Voice Support:</b> +91 9171233333 ANAX Customer Support Team personnel answers to service requests and assigns work to ANAX INFOTECH Pvt. Ltd., technicians to perform the Call-Out Services. Service requests for non-urgent service repair work is assigned to ANAX INFOTECH Pvt. Ltd., field operations
<b>Call-out Service</b>	Call-out Service is designed to solve unexpected equipment failure, equipment stoppage or erratic operation, requiring immediate attention of a ANAX INFOTECH Pvt. Ltd., Technician
<b>Service Repair</b>	Service Repair is repairing a malfunction or broken or damages component in the equipment. By identifying service repair needs in the equipment condition during the maintenance visits, ANAX INFOTECH Pvt. Ltd., is able to perform Service Repair visit even before the equipment's operation is disrupted.



Registered Office:  
176 Twin Building, 2nd Floor (Anjappar Hotel  
Upstairs, Thoothukudi, Tamil Nadu 628003.

Voice Support: +91 9171233333 (8AM - 10PM)  
[info@anaxinfotech.com](mailto:info@anaxinfotech.com)

## Appendix1

### TERMS AND CONDITIONS OF NON-COMPREHENSIVE MAINTENANCE CONTRACT

**1. Period of Contract:** The contract is valid for the period agreed in the above Contract Details. This may be renewed periodically subject to rendering of satisfactory service & fulfilling the term & conditions.

**2. Payment Term:** Payment shall be made 100% advance against approved quote.

**3. Scope:** Maintenance of the CCTV Surveillance System includes Camera Visibility Test.

**4. Non coverage:** Replacement or repairing of CCTV Materials & Accessories which are in faulty condition are not covered under this contract, however ANAX INFOTECH shall arrange for the same on chargeable basis based on Customer's consent. If it is arranged by Customer, the equipment parts replaced must be new and equivalent in performance of existing parts.

Product replacements under manufacturer warranty as per manufacturers terms and conditions.

**5. Additional Charges:** The cost includes the travelling cost for rendering service throughout agreed period for one or all locations & for one or all systems. Additional charges will be applicable for the replacement or repair of spares as mentioned in above clause. Password Reset, Relocation of products and Data Back-up services will be provided on chargeable basis.

Worn-out product repairs will be carried out based on terms & conditions of ANAX InfoTech's service vendor on chargeable basis.

#### 6. Frequency of Visits

Customer site will be visited depends upon the AMC Plan.

**7. Working Hours:** The maintenance work shall normally be done during working hours of the customer. However in case of emergency, maintenance may be done beyond office hours and even on holidays, prior arrangement through proper communication should be worked out in all cases.

**8. Final Authority:** The final authority for payments will be Head of the Organization offering the service.

**9. Customer Support:** File your maintenance requests to ANAX INFOTECH Voice Support: +91 9171233333 E-mail: [info@anaxinfotech.com](mailto:info@anaxinfotech.com)

For  
ANAX INFOTECH Pvt. Ltd.  
Thoothukudi, Tamil Nadu 628003.

For  
PSN College of Engineering and Technology  
Melathediyoor, Tirunelveli-627152.



16  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOR, PALAYANKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152

Registered Office:  
176 Twin Building, 2nd Floor (Anjappar Hotel  
Upstairs, Thoothukudi, Tamil Nadu 628003.

Voice Support: +91 9171233333 (8AM - 10PM)  
[info@anaxinfotech.com](mailto:info@anaxinfotech.com)

# SATHYA Technosoft (I) Pvt. Ltd.,

## CCTV Annual Maintenance Contract

Date:

Reference No: STS 2 1 1 1 1 2 1 0 8 0

### Parties Details

Customer	SATHYA Technosoft (I) Pvt. Ltd., SATHYA Technosoft (I) Pvt. Ltd., 371, Palayamkottai Road, Tuticorin-628 002 Tamil Nadu Tel: 9952 300 300 Contact Person: Contact Person's Ph. No:
Company Name: PSN COLLEGE OF ENGINEERING AND TECHNOLOGY Registered Address: PSN Nagar, Melathediyoor, Pallayam Kottai, Tirunelveli - 627152 Contact Person Sudhakar Contact Person's Ph. No: 9597970444	

### Site Address

Company Name:PSN COLLEGE OF ENGINEERING AND TECHNOLOGY  
Registered Address:PSN Nagar, Melathediyoor, Pallayam Kottai, Tirunelveli - 627152

This contract has been prepared in two identical counterparts, one for each party. We hereby agree to the General Terms and conditions as detailed in the Appendix1 & 2.

SATHYA Technosoft (I) Pvt. Ltd.,

Signed by the Customer

Signed by SATHYA  
Technosoft (I) Pvt. Ltd.,



Company Seal

Contract No

--	--	--	--	--	--	--

Dr P SELVAKUMAR M.E. Ph.D.

EXECUTIVE DIRECTOR

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST 627 152

Date: 24/11/2002

Date:

PRINCIPAL

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK

Voice Support +91 9841918001/9841918002  
24x7 Online Support: www.sathyainfo.com

Registered Office:  
SATHYA Technosoft (I) Pvt. Ltd.,  
1, Palayamkottai Road, Tuticorin - 628002.  
Tamilnadu, India

### Contract Details

Commencement date	23 Dec 2021
Contract duration period	1 Year
Contract renewal Date	23 Dec 2022
Plan Type & No of Visits	1 Scheduled visit per Month(12 visits/Year) #Each additional visit will be on Chargeable basis #The contract does not include any spare replacement #GST is additional #100% payment Advance payment #Backup of data is client scope
Payment terms	Amount as mentioned in Appendix 2 to be paid in advance as per the AMC Plan
SATYA Technosoft (I) Pvt. Ltd., normal working hours	10.AM to 6.PM(Mon-Sat)

#### Equipment Covered Under AMC

Equipment Name	Brand Name	Model No.	Serial No.	Date of Purchase	Warranty Period
CCITV Camera	Hikvision	HIKVISION IP CAMERA DS-2CD120P-I3 (1MP 4MM)		19 <sup>th</sup> July 2019	19 <sup>th</sup> July 2020
CCITV Camera	Hikvision	HIKVISION IP CAMERA DS-2CD130P-I(1MP)		19 <sup>th</sup> July 2019	19 <sup>th</sup> July 2020
CCITV NVR	Hikvision	HIKVISION NVR DS-7P16NI-Q2		19 <sup>th</sup> July 2019	19 <sup>th</sup> July 2020
CCITV NVR	Hikvision	HIKVISION NVR DS-7P32NI-K2 (32CH)		19 <sup>th</sup> July 2019	19 <sup>th</sup> July 2020



III - Quarter of Office:  
SATYA Technosoft (I) Pvt. Ltd.,  
Palayamkottai Road, Tuticorin - 628002,  
Tamilnadu, South India

PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST - 627 152

Voice Support: +91 9952300300 (9AM - 9PM)  
24x7 Online Support: [www.sathyainfo.com](http://www.sathyainfo.com)

## Appendix1

### TERMS AND CONDITIONS OF NON-COMPREHENSIVE MAINTENANCE CONTRACT

**1. Period of Contract:** The contract is valid for the period agreed in the above Contract Details. This may be renewed periodically subject to rendering of satisfactory service & fulfilling the term & conditions.

**2. Payment Term:** Payment shall be made 100% advance against approved quote.

**3. Scope:** Maintenance of the CCTV Surveillance System includes Camera Visibility Test, DVR Recording Test, DVR Settings Verification, and Disk Error Check.

**4. Non coverage:** Replacement or repairing of CCTV Materials & Accessories which are in fault condition are not covered under this contract, however SATHYA shall arrange for the same on chargeable basis based on Customer's consent. If it is arranged by Customer, the equipment parts replaced must be new and equivalent in performance of existing parts.

Product replacements under manufacturer warranty as per manufacturers terms and conditions.

Data backup & providing product stand-by are not covered in this contract.

**5. Additional Charges:** The cost includes the travelling cost for rendering service throughout agreed period for one or all locations & for one or all systems. Additional charges will be applicable for the replacement or repair of spares as mentioned in above clause. Password Reset, Relocation of products and Data Back-up services will be provided on chargeable basis.

Worn-out product repairs will be carried out based on terms & conditions of Sathya's service vendor on chargeable basis.

#### 6. Frequency of Visits

Customer site will be visited depends upon the AMC Plan in Appendix 2.

**7. Working Hours:** The maintenance work shall normally be done during working hours of the customer; however in case of emergency, maintenance may be done beyond office hours and even on holidays, prior arrangement through proper communication should be worked out in all cases.

**8. Final Authority:** The final authority for payments will be Head of the Organization offering the service.

**9. Customer Support:** File your maintenance requests to Sathya. Voice Support +91 9952300300  
Online Support: support@sathyainfo.com

#### 10. Recommended Electrical Wirings

- Proper earthing, proper power plug provisions for the DVR side along with UPS connections
- Proper arrangements in camera side enclose all the camera cables into the box
- All the cables lay into the PVC or any other pipe.
- Must avoid the CCTV cables and electrical cables together



**PRINCIPAL**  
**PGM COLLEGE OF ENGINEERING & TECHNOLOGY**  
**MELATHEDIYODUR, PALAYAMKOTTAI TALUK**  
**TIRUNELVELI DIST - 627 152**



Registered Office:

SATHYA Technosoft (I) Pvt. Ltd.,  
21, Palayamkottai Road, Tuticorin – 628002.  
Tamilnadu – South India

Voice Support: +91 9952300300 (9AM – 9PM)  
24x7 Online Support: [www.sathyainfo.com](http://www.sathyainfo.com)

## Appendix 2

### AMC PLAN AND PAYMENT DETAILS

Plan Type: 1 Year

No of Visits:  12 Visits in a Year  4 Visits in a year  On Call Basis

Items	Charges
127 Cameras + 5 NVR	Rs.25000/- (Standard Charge)

#### Details:

Items - 127 Cameras + DVR

#### Charges

120 Cameras + 5 NVR = Rs. 25000/- (Standard Charge)

Additional Cameras = No. of additional cameras \* Charge /camera= Rs.

Additional 1 DVR = Rs. ....

Total Amount = Rs. ....

Signature

For Customer

Dr. P SELVAKUMAR M.E. Ph.D.  
EXECUTIVE DIRECTOR  
P.S.N COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOD, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST 627 152



Signature

For SATHYA Technosoft (I) Pvt. Ltd.



PRINCIPAL  
P.S.N COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOD, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST - 627 152

Registered Office:  
SATHYA Technosoft (I) Pvt. Ltd.,  
21, Palayamkottai Road, Tuticorin - 628002,  
Tamilnadu, South India

Ref: GS/Tvl/2021105/2021 - 22

Date: 01.10.2021

## AGREEMENT FOR THE MAINTENANCE OF ELEVATORS

M/s P S N College of Engineering, (G + 6 Floors/13 persons) Tirunelveli.

Herein after to as the "Owner"

### Equipment Type & Maintenance price Details

Equipment Type	: Passenger Elevators
Type of Contract	: Comprehensive Type
Contract price	: <u>Rs. 65,000/-</u> Per lift per annum (Sixty Five Thousand only) Hence for Two lifts <u>Rs. 1,30,000/-</u> (One lac Thirty thousand only)
Period of Contract	: Start date after signing of the contract.

GS LIFTS agrees upon the terms and condition of this agreement (attached) to provide the Maintenance and repairs services specified in the condition. (The Services) in respect of the equipment located at the above premises.

In consideration of the provision by GS LIFTS of the services the owner agrees to pay the maintenance fees of the payment dates.

This agreement shall commence on the commencement date and will continue for the period of the agreement specified above, unless terminated or suspended in accordance with the condition of the contract and will continue thereafter on an monthly basis unless terminated by either party giving to the other a one month's advance notice.

Accepted on behalf of  
For GS LIFTS

(Authorized Signature)



Accepted on behalf of  
The "OWNER"

Dr. P SELVAKUMAR M.E. Ph.D.  
EXECUTIVE DIRECTOR  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYODUR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. 627 152



10/94E, Erumbukadu & (P.O.), Nagercoil, Kanyakumari Dist., Pin : 629 004.

Ph : 04652 264544, | Mob : 8489565655, 9486629511

Email : gslifts@gmail.com | Website : www.gslifts.in PRINCIPAL

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYODUR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST - 627 152

## GS LIFTS»

### AGREEMENT FOR ANNUAL MAINTENANCE OF ELEVATORS

BUILDING NAME	PSN COLLEGE
LOCATION	TIRUNELVELI
MAKE & TYPE OF ELEVATORS	JOHNSON
No.OF.ELEVATORS	TWO
TYPE OF CONTRACT	COMPREHENSIVE

### COMPREHENSIVE CONTRACT

#### SECTION : 1

GS Lifts Shall:

1. Service the lifts at regular intervals and as frequently as the company deems necessary based on the age, nature and condition of the elevator and we will take all reasonable care and maintain the lift equipment in safe and proper working condition.
2. Carry out the service work whenever possible on a day convenient to the customer other than Sunday & Holidays and during regular working hours.
3. Assume no responsibility for refinishing repairing the following non-proprietary items of the lift equipment and we have not included for the same in this contract. Car enclosure's car flooring, hoist way enclosure, hoist way and car door, door and gate handles, door beading, door frames, sills push box covers in landings and car electric incoming mains, main switch, EPABX Telephone intercom, fan and light fittings, mirror, alarm bell and buzzer, emergency light, alarm device, main VVVF drive, A R D and batteries.
4. Be entitled to depute its authorized service personal to attend all call back during normal working hours, free of charges.



**PRINCIPAL**  
**PSN COLLEGE OF ENGINEERING & TECHNOLOGY**  
**MELATHEDIYODUR, PALAYAMKOTTAI TALUK**  
**TIRUNELVELI DIST - 627 152**



## GS LIFTS»

5. Repair overhaul the lift parts when in our judgment, the conditions warrant and the old parts will be removed and this will become our property.
6. Not included in this contract to depute its service personnel for any other work, which does not come under the purview of the contract, if it becomes necessary whether required by statutory body or otherwise, the company shall charge you extra and it shall be payable in advance.
7. Replenish the Gear and Motor bearing with necessary GS Lifts Lubricants whenever necessary and all parts of the lift will be checked, cleaned and lubricated to keep them, both mechanically and electrically in perfect working condition.
8. Carry out according to its standards customary annual safety test to examine all safety devices. The company will not be required to make any other tests. The company will not be required to install new attachments or to make replacements with parts of a different design to the elevator whether or not recommended or directed by Insurance Companies or by Government or Non-governmental authorities.
9. Not be liable for repairing or replacing any lift which in our opinion is damaged or broken due to accident or negligence or misuse or willfully damaged by the users or third party or due to reasons over which the company has no control.
10. Replace any components or parts of the lift, if it becomes necessary, on account of the reasons quoted under clause No.9, such work will be carried out after obtaining your consent and the cost of the same will be to your account, in addition to the contract charges.
11. By notice in writing to the customer forthwith terminate this contract and/or not be liable for any loss and/or not make replacements and repairs free of charge, in any of the following circumstances:
  - (a) If the customer fails to pay the company the amount as and when due under this contract.



PRINCIPAL  
PGN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST - 627 152

## GS LIFTS»

- (b) Where the company is prevented for a continuous period of 3 months from performing its duties for any reason and for any circumstances beyond its control.
- (c) Where without the company's prior written consent, any work within the scope of this contract is carried out by anyone other than the company's service personnel or Agents.
- (d) Where, after written notice to the customer about important work or replacement to be carried out, which are not within the scope of this contract, the customer refuses or fails to carry out the said work/replacements within a reasonable time.
- (e) Where equipment is not prevented from misuse by the customer.
- (f) Where materials, components, parts or assemblies are not longer available due to obsolescence or if they are permanently taken out of production by the original supplier, when the supply and use of alternative replacement materials, components, parts or assemblies (as the case may be) shall be at the cost of the customer. In the event, the company considers themselves unable to supply any materials or parts for the purpose of this agreement, this agreement shall forthwith terminate without prejudice to the company's accrued rights and without any liability to the company for such termination.
- (g) Where damage or delay is caused due to strikes, lockouts, civil commotion, war, theft, floods, riots, explosion or act of God or cause beyond our control.
- (h) Where damage is caused to all or part of the elevator as a consequence of a faulty electrical system, fire, water seepage, flooding etc. It is recommended that the client takes adequate protection from insurance or similar companies to cover equipment for damages that can occur due to such cases. In such an event, the cost of repair or replacement shall be reimbursed to us without any conditions or limitations.



PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST - 627 152

## GS LIFTS»

### Section 2

#### The Customer Shall:

1. Keep the machine room under lock and key to prevent pilferage and theft.
2. Keep the sills machines room and put clean
3. Notify the company of any malfunction what sever of the elevator.
4. Prevent misuse or vandalism of the elevator.
5. Ensure that two trained persons in the building are available for emergency rescue of trapped passengers.
6. Not allow any other persons, either his own or a third party to tamper with elevator or rectify any of the elevator components during the subsistence of this contract with the explicit understanding that any breach of this clause shall relieve the company of all further obligations under this contract.

### Section 3

#### General Terms:

1. If it becomes necessary to replace any components of parts of the lift on account of the reason quoted under clause No.9 (Section 1). Such work shall will be to your account.
2. The company is not expected to assume liability for injury (other than to its employees) or damage to property resulting from or caused by the elevator during its operation.
3. In case of a reported being attended by the company which it finds is due to extraneous causes such as failure of power supply, improper closing of doors, unauthorized interference by strangers over which the company has no control, a service charges of Rs.200/- shall be levied.
4. In case of any dispute between us, the matter shall be settled by arbitration in Chennai and the Chennai court shall has exclusive jurisdiction.
5. During the period of servicing, the lift shall not be available for your use but the lift operator should be present till the servicing work is completed.



  
PRINCIPAL  
P.S.N. COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST - 627 152

## GS LIFTS»

6. The service contract shall be for a minimum period of one year.
7. The quotation is valid for a period of 30 days from the date of offer and thereafter subject to our confirmation.
8. Upon notification by the customer of a breakdown or failure in the elevator, the company shall send as soon as may reasonably be possible during the company's normal working hours, a technician to carry out necessary repairs in order to restore the elevator to satisfactory working condition.
9. As a token of your acceptance please sign and return to us the original and duplicate copies of the contracts together with the payment. We shall sign and return the original contract form for your records.

### Contract Charges:

Our price for providing the regular comprehensive maintenance contract as detailed herein above is Rs. 65,000/- (Sixty Five thousand only) per lift per annum. Hence for two lifts Rs. 1,30,000/- (One lac Thirty Thousand only)

Contract period: 10<sup>th</sup> October 2021 to 09<sup>th</sup> October 2022,

Yours truly,



Accepted in Duplicate by Owner

Or His Representative with seal

Dr. P SELVAKUMAR M.E. Ph.D.

EXECUTIVE DIRECTOR

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST - 627 152



PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST - 627 152

## GS LIFTS»

### PAYMENT TERMS

50% as advance

50% as post dated cheque (after completion of first six months date)

Accepted on behalf of  
GS Lifts



(Authorized Signatory)

Accepted on behalf of PSN college

  
(Authorized Signatory)

Dr. P SELVAKUMAR M.E. Ph.D.  
EXECUTIVE DIRECTOR  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYODU, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST 627 152



PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYODU, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST - 627 152



## SOUTH ASIYA A/C, ENGG. COM

87/2, Sathy Moorthy Street, Tirunelveli Town.

Authorised Sales & Service  
Window & Split A/c & Stabilizers

Date: 11.10.2021

### TERMS AND CONDITIONS FOR ANNUAL MAINTENANCE FOR AIRCONDITIONERS

1. The maintenance contract entered is for one year from 11.10.2021 to 10.10.2022
2. Checking and servicing the unit 4 times in a year.
3. Attending to the unit when called upon by you during normal working hours.
4. Repairing the units or parts thereof, as also overhauling the unit including replacing parts free of charge in our Service Station. If required as a result of fair wear and tear.
5. Providing a service unit as and when available, free of charge during repair / overhaul of the unit in our Service Station.
6. Owner will provide and maintain the electrical installation outside of the room Air conditioner through him licensed Electrical Contractor and will not be responsible for damages due to defect in the electrical installation.
7. The owner of the room air conditioner will have to give us prompt written intimation of any change of location of the unit and also get the new Installation approved by us. We will assume no responsibility for service in case installation of change of location is not given.
8. We have the option to terminate the MAINTENANCE SERVICE if the room air conditioner Serviced / repaired by any part other than ourselves or our authorized dealers in case of the change of ownership or any reason whatsoever.
9. Consequential damages and losses of any nature whatsoever are not covered under the service scheme
10. Compressor failure is not covered under AMC PSNCET has to bear the compressor cost, but there will be no service charges.
11. This maintenance service scheme does not cover damage to machines / ancillaries because of environmental conditions
12. A Voltage supply of +230-10V should be ensured to the supply point to the air conditioner
13. You will have to provide a suitable voltage stabilizer to withstand voltage fluctuations
14. The air conditioners Front grills, outer cover, voltage stabilizer and panels for split units are not covered under this contract
15. Tinkering charges extra
16. At the time of undertaking AMC of the Air-Conditioner which should be in working condition
17. We also take AMC for all brands of AIR CONDITIONERS

For,  
**SOUTH ASIYA A/C, ENGG. COM.**  
87/2, Sathy Moorthy Street,  
Tirunelveli Town.



For,  
**PRINCIPAL**  
PSN College of Engineering and Technology  
Melathediyoor, Tirunelveli

**PRINCIPAL**  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.



**VECTRA**  
COMPUTER SOLUTIONS

No. 41, North Veli Street, II Floor  
MADURAI-625 001 Tamil Nadu  
Tel 0452-4370811 Telefax 2350611  
Sales 98421-27779 Service 98421-35777  
E-mail info@vectras.org

Regd. No. 562 • CST No. 113777 • Area Code : 252 • ST No. AADFV0487D 5100\*

PSN College of Engineering and Technology,

31<sup>st</sup> July 2016

5 years Warranty Certificate for Digital Persona Biometric Scanner

Sir/Madam we are pleased to inform you that, the 5 years Warranty Certificate for 90 nos. of Uru Biometric Scanner is issued to us from the distributor M/s. ID Tech Solutions which are based in USA. The warranty will be provided by the distributor through M/s. Vectra Computer Solutions 0452-4370811.

Thanking you for your kind information.

Yours Sincerely  
Vectra Computer Solutions

Dr. Ganesan  
General Manager



**PRINCIPAL**  
**PSN COLLEGE OF ENGINEERING & TECHNOLOGY**  
**MELATHEDIYODOR, PALAYAMKOTTAI TALUK**  
**TIRUNELVELI DIST - 627 152**

Show Room

Madurai 625 001 Phone : 0452-4380809

## Warranty Certificate

The Uru5100 Finger Print Scanners billed to Vectra Computer Solution, No. 41, 1st Floor, North Wall Street, Madurai - 625 001 has 5 (Five) years warranty from the date of billing. The serial numbers for 90 nos. uru5100 Finger Print Scanners are as below.

1 D600B07960	31 D600B07990	61 D600B18196
2 D600B07961	32 D600B07991	62 D600B18197
3 D600B07962	33 D600B07992	63 D600B18198
4 D600B07963	34 D600B07993	64 D600B18199
5 D600B07964	35 D600B07994	65 D600B18200
6 D600B07965	36 D600B07995	66 D600B18201
7 D600B07966	37 D600B07996	67 D600B18202
8 D600B07967	38 D600B07997	68 D600B18203
9 D600B07968	39 D600B07998	69 D600B18204
10 D600B07969	40 D600B07999	70 D600B18205
11 D600B07970	41 D600B08000	71 D600B18206
12 D600B07971	42 D600B08001	72 D600B18207
13 D600B07972	43 D600B08002	73 D600B18208
14 D600B07973	44 D600B08003	74 D600B18209
15 D600B07974	45 D600B08004	75 D600B18210
16 D600B07975	46 D600B08005	76 D600B18576
17 D600B07976	47 D600B08006	77 D600B18577
18 D600B07977	48 D600B08007	78 D600B18578
19 D600B07978	49 D600B08008	79 D600B18579
20 D600B07979	50 D600B08009	80 D600B18580
21 D600B07980	51 D600B18186	81 D600B18581
22 D600B07981	52 D600B18187	82 D600B18582
23 D600B07982	53 D600B18188	83 D600B18583
24 D600B07983	54 D600B18189	84 D600B18584
25 D600B07984	55 D600B18190	85 D600B18585
26 D600B07985	56 D600B18191	86 D600B07341
27 D600B07986	57 D600B18192	87 D600B07342
28 D600B07987	58 D600B18193	88 D600B07343
29 D600B07988	59 D600B18194	89 D600B07344
30 D600B07989	60 D600B18195	90 D600B08853



Sumanth Balachandran  
Principal



**PRINCIPAL**  
**PSN COLLEGE OF ENGINEERING & TECHNOLOGY**  
**MELATHEDIYOOR, PALAYAMKOTTAI TALUK**  
**THIRUNELVELI DIST - 627 152**

JAS, ANZ



ISO 9001:2000 Certified Company

## ONLINE IT SHOPE

Opp.Axis Bank, Market Jn., Hill Palace Road, Tripunithura, Kerala - 682 301  
Ph: 9846244215, 9349337624, 8281841160

Date: 14-11-2021

### AMC AGREEMENT

We Online IT Shope, Tripunithura, Kerala shall maintain the various Computer Systems and other peripherals specified in this Agreement on terms and conditions hereinafter mentioned for PSN College of Engineering and Technology,Melathediyoor,Tirunelveli-627152

#### **Terms of the Agreement:**

These agreements shall remain in force for the period from 15th November 2021 to 14th November 2022. It shall be open to either party to terminate the Agreement any time during the said period by giving one month notice.


#### **NON COMPREHENSIVE ANNUAL MAINTENANCE CONTRACT:**

Under this following services will be provided.

1. Quarterly preventive maintenance and checks.
2. Operating system level support without any spare part.

For Online IT Shope

Tripunithura,Kerala

  
Shyng Anthony

For PSN College of Engineering and Technology

Melathediyoor,Tirunelveli



PRINCIPAL

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYANIKKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.





**APJ Multi Service Centre**

### **ANNUAL MAINTENANCE CONTRACT**

This Annual Maintenance Contract is for the Six RO Plant of Capacity 250 l/hr, installed at PSN College of Engineering and Technology (Autonomous), Melathediyoor, Tirunelveli-627152.

The following Service will be done as part of the Annual Maintenance Contract (AMC)

- 1) Every 2 (Two) months, our service Engineer, will visit the site, where the equipment is installed, and free service will be done.
- 2) During the above service, 20 inch Micron Filter (2 Nos.) will be changed at free of cost.
- 3) Activated carbon 25kg Sand - 25kg, Membrane filter will be changed at the AMC, the College has to pay for it.
- 4) For the spaces in the equipment installed, during the AMC period, 1 year replacement Warranty is covered, and there will be no labour charges also.
- 5) During the period of the AMC, Complaints (if any) is registered, our service Engineer will attend the complaint at no extra cost within a day.
- 6) This AMC is valid for the period of one Year from 11.11.2021.
- 7) This Annual Maintenance Contract cost is Rs.23,000/- (**Rupees twenty three thousand only**)
- 8) Dosing Pump, Raw water and RO Pump, Panel board with Frame, Sand and carbon vessels are not included at this AMC.

For

APJ Multi Service centre  
Tirunelveli

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152,

For

Principal

PSN College of Engineering and Technology

PRINCIPAL

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.

**GERSHOM ENGINEERING ENTERPRISES**  
**FIRE PROTECTION SAFETY ENGINEERS**

Row D/2, Block NO.10, Transit Camp, Mahim (E) Mumbai - 400 017

Tamil nadu Government Approved

Entrepreneurs Memorandum No. 330291100228

GSTIN :33CCKPS5410C2ZV

# Certificate

This is to certify that

we have tested refilled &amp; serviced

FIRE EXTINGUISHER OF  
**M/s. PSN COLLEGE OF  
 ENGINEERING AND TECHNOLOGY**  
 On **01-11-2021**  
 and found the same in good working condition  
 if is valid upto **01-11-2022**

Type of Extinguisher	Capacity	Quantity
Soda Acid Type		
Foam Type	FOAM 4	02 Nos
D.C.P. Type	50 Ltrs	
Co2 Type		
BCF Halon	DCP	- 01 Nos.
Water Co2		
ABC	25 Kgs	
FF, Mechanical Foam		

For GERSHOM ENGINEERING ENTERPRISES

B.S.I.R.C. No 40017/S-989 w.e.f. 1-4-96  
C.S.I.R.C. No 40017/C-779 w.e.f. 1-4-96

Proprietor



PRINCIPAL  
 PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
 MELATHEDIVORE, PALATHURU/TALUK  
 TIRUNELVELI/DIST. - 627 152.

Tel : 2402 45 75 / 2404 00 16

**GERSHOM ENGINEERING ENTERPRISES**  
**FIRE PROTECTION SAFETY ENGINEERS**

Row D/2, Block NO.10, Transit Camp, Mahim (E) Mumbai - 400 017

Tamil nadu Government Approved

Entrepreneurs Memorandum No. 330291100228

GSTIN :33CCKPS5410C22V

# Certificate

This is to certify that

we have tested refilled & serviced

M/s. **PSN COLLEGE OF  
ENGINEERING AND TECHNOLOGY**

on..... **01-11-2021**

and found the same in good working condition.


if is valid upto... **01-11-2022**

Type of Extinguisher	Capacity	Quantity
Soda Acid Type	CO2 4.5kg	03
Fome Type	CO2 2kg	02
D.C.P. Type	Foam 10	04
CO2 Type	DCP 5kg	09
BCF Halon	DCP 6kg	10
Water CO2	DCP 2kg	02
ABC	DCP 10kg	04
AFFF, Mechanical Foam	DCP 10kg	04

For GERSHOM ENGINEERING ENTERPRISES

B.S.T.R.C. No 40017/S-989 w.e.f. 1-4-96  
C.S.T.R.C. No 40017/C-779 w.e.f. 1-4-96

Proprietor





# CALIBRATION OF EQUIPMENT- CERTIFICATES

## PRINCIPAL

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYODU, PALAYANKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.



# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008. Tamil Nadu. India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

CERTIFICATE NO: GSR/CC/T202210-01

Page No: 1 of 1

**Customer Name & Address :**

M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY.,  
Melathediyoor,  
Tirunelveli - 627152.

Receipt Date : 20-Jan-22  
Calibration Date : 20-Jan-22  
Calibration Due : 19-Jan-23  
Issue Date : 21-Jan-22

**Details of Device Under Calibration (DUC)**

Description : DC VOLTMETER	Identification No : PSMCET/EEE/VM/01
Make : OXFORD	Range : 0 to 30 VDC
Model : MR-100	Least Count : 0.5 VDC
SI.No : --	Location : EEE Department. DUC Condition : SATISFACTORY

**Environmental Conditions**

Environmental Details	Temperature: 27.8°C	Relative Humidity	61% Rh
-----------------------	---------------------	-------------------	--------

**Standard Operating Procedure Details**

Calibration Procedure No	SOP-T-01	Calibration done at	SITE
--------------------------	----------	---------------------	------

**Reference Standards Details**

S.No	Description	Make/ SI No:	Certificate No	Validity
1	6 1/2 DIGITAL MULTIMETER	TW00026191	MKS/ET/21-22/205-01	29-Jul-22
1	MULTIPROCESS CALIBRATOR	HT160100059	MKS/ET/21-22/205-02	29-Jul-22

**Calibration Result**

S.No.	STANDARD INSTRUMENTS READINGS	DEVICE UNDER CALIBRATION READINGS	DEVIATION	EXPANDED UNCERTAINTY ( $\pm$ )	STATUS
	VDC	VDC	VDC	VDC	
1	0.00	0.0	0.00	0.64	PASS
2	5.07	5.0	0.07	0.64	PASS
3	10.11	10.0	0.11	0.64	PASS
4	15.23	15.0	0.23	0.64	PASS
5	20.37	20.0	0.37	0.64	PASS
6	30.41	30.0	0.41	0.64	PASS

**TRACEABILITY OF STANDARDS**

The standard used for calibration are traceable to national standard

G.MUTHURAJ  
(Calibration Engineer)

CALIBRATED BY



C. RAHUL SELVAN  
(Tech.manager)

PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI  
TIRUNELVELI DIST. - 627 152.  
AUTHORIZED SIGNATORY

# GENERAL SCIENTIFIC RESEARCH LABORATORY

## सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008. Tamil Nadu. India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

### CALIBRATION CERTIFICATE

CERTIFICATE NO: GSR/CC/T202210-02				Page No:1 of 1	
<b>Customer Name &amp; Address :</b>  M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY., Melathediyoor, Tirunelveli - 627152.		Receipt Date : 20-Jan-22	Calibration Date : 20-Jan-22	Calibration Due : 19-Jan-23	
		Issue Date : 21-Jan-22	DUC Condition : SATISFACTORY		
<b>Details of Device Under Calibration (DUC)</b>					
Description : DC AMMETER	Identification No : PSNCET/EEE/AM/01	Make : OXFORD	Output Range : 0 to 100 mA	Model : MR-100	
SI.No : ---	Least Count : 2 mA	Location : ELECTRICAL LABORATORY			
<b>Environmental Conditions</b>					
Environmental Details	Temperature: 25.8° C	Relative Humidity	61% Rh		
<b>Standard Operating Procedure Details</b>					
Calibration Procedure No	SOP-E-04	Calibration done at	SITE		
<b>Reference Standards Details</b>					
S.No	Description	Make/ SI No:	Certificate No	Validity	
1	6 1/2 DIGITAL MULTIMETER	TW00026191	MKS/ET/21-22/205-01	29-Jul-22	
2	MULTIPROCESS CALIBRATOR	HT160100059	MKS/ET/21-22/205-02	29-Jul-22	
<b>Calibration Result</b>					
S.No.	STANDARD INSTRUMENTS READINGS	DUC VALUE	DEVIATION	EXPANDED UNCERTAINTY ( $\pm$ )	STATUS
	mA	mA	mA	mA	
1	20.19	20	0.19	1.21	PASS
2	40.37	40	0.37	1.21	PASS
3	60.58	60	0.58	1.21	PASS
4	80.75	80	0.75	1.21	PASS
5	100.98	100	0.98	1.21	PASS
<b>TRACEABILITY OF STANDARDS</b>					
The standard used for calibration are traceable to national standard					

G.MUTHURAJ  
(Calibration Engineer)

CALIBRATED BY



C. RAHUL SELVAN  
(Tech.manager)

PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.  
AUTHORIZED SIGNATORY

# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला




101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008, Tamil Nadu, India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

Cert. No	:	GSR/CC/T202210-03	Page	: 01 of 05
Customer	:	M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY		
Address	:	Melathediyoor, Tirunelveli - 627152.		
Date of Received	:	20-Jan-22	Next Due Date	: 19-Jan-23
Date of Calibrate	:	20-Jan-22	Date of Issue	: 21-Jan-22
<b>DESCRIPTION &amp; IDENTIFICATION OF INSTRUMENTS</b>				
Instrument Name	:	DIGITAL MULTIMETER		
Manufacturer	:	MASTECH	Serial Number	: ----
Model Number	:	MAS 830L	Range	: MULTIRANGE
Location	:	EEE Department.	Resolution	: MULTIRANGE
<b>ENVIRONMENTAL CONDITIONS</b>				
Ambient Temperature :	24.4 °C	Relative Humidity	:	49.9 %r.h
<b>METHOD OF CALIBRATION</b>				
GSR LAB organisation and practices are derived from ISO/IEC 17025:2017(E). It therefore meets the relevant requirements of ISO 9001:2008(E) when acting as the supplier providing calibration result. The described instrument has been calibrated at GENERAL SCIENTIFIC RESEARCH LABORATORY under the ambient conditions stated above				
<b>STANDARD INSTRUMENT USED</b>				
INSTRUMENT NAME	SL.NO/ID.NO	CAL.DATE	DU DATE	TRACEABILITY
MULTI PROCESS CALIBRATOR	HT160100059	30-Jul-21	29-Jul-22	MKS
HIGH VOLTAGE TESTER	GSR/EMI/15	04-Sep-21	03-Sep-22	Meso
DIGITAL MULTIMETER	TW00026191	30-Jul-21	29-Jul-22	MKS
<b>TRACEABILITY OF STANDARDS</b>				
The standard used for calibration are traceable to national standard				



# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008. Tamil Nadu. India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

Cert.No : GSR/CC/T202210-03 Page : 02 of 05

### RESULTS OF CALIBRATION

#### DC VOLTAGE

Sr.	RANGE	NOMINAL VALUE DC (V)	INSTRUMENT READING DC (V)	DEVIATION DC (V)	MEASUREMENT UNCERTAINTY ± DC(V)
1	200 mV	10.097	10.1	0.003	0.002
		100.187	100.2	0.013	0.002
		199.681	199.7	0.019	0.002
2	2 V	1.005	0.997	-0.008	0.008
		1.021	1.007	-0.014	0.009
		2.007	1.989	-0.018	0.010
3	20 V	1.005	1.00	-0.005	0.075
		9.997	10.03	0.033	0.075
		19.887	19.99	0.103	0.085
4	200 V	9.77	10.1	0.33	0.711
		99.97	100.4	0.43	0.738
		198.91	199.4	0.49	0.794
5	600 V	99.11	100	0.89	0.711
		298.91	300	1.09	0.738
		597.71	599	1.29	0.794

#### AC VOLTAGE

Sr.	RANGE	NOMINAL VALUE AC (V)	INSTRUMENT READING AC (V)	DEVIATION AC (V)	MEASUREMENT UNCERTAINTY ± AC(V)
1	200 V	1.097	1.1	0.003	0.002
		99.321	99.7	0.379	0.002
		198.941	199.4	0.459	0.002
2	600 V	98.11	99	0.89	0.008
		298.21	299	0.79	0.009
		596.83	598	1.17	0.010



# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008. Tamil Nadu. India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

Cert.No : GSR/CC/T202210-03 Page : 03 of 05

### RESULTS OF CALIBRATION

#### DC CURRENT

Sr.	RANGE	NOMINAL VALUE ( $\mu$ A)	INSTRUMENT READING ( $\mu$ A)	DEVIATION ( $\mu$ A)	MEASUREMENT UNCERTAINTY $\pm$ ( $\mu$ A)
1	20 $\mu$ A	1.07	1.03	-0.040	0.078
		5.05	5.00	-0.050	0.078
		10.07	10.00	-0.070	0.078
		20.01	19.95	-0.060	0.078
2	200 $\mu$ A	19.97	20.1	0.13	0.003
		50.21	50.4	0.19	0.003
		100.51	100.7	0.19	0.003
		199.31	199.6	0.29	0.003
3	2 mA	0.217	0.2	-0.017	0.008
		0.517	0.5	-0.017	0.008
		1.024	1.0	-0.024	0.008
		1.933	1.9	-0.033	0.008
4	20 mA	2.08	2.0	-0.08	0.041
		5.17	5.0	-0.17	0.041
		10.09	9.9	-0.19	0.041
		20.13	19.9	-0.23	0.041
5	200 mA	9.51	9.8	0.29	0.175
		49.31	49.6	0.29	0.175
		98.99	99.3	0.31	0.175
		198.11	198.7	0.59	0.175
6	10 A	0.989	1	0.011	0.605
		4.961	5	0.039	0.605
		7.917	8	0.083	0.605
		8.895	9	0.105	0.605

G.MUTHURAJ (Calibration Engineer) 	PRINCIPAL PSN COLLEGE OF ENGINEERING & TECHNOLOGY MELATHEDIYOOR, PALAYAMKOTTAI TALUK TIRUNELVELI DIST. - 627 152. 	C. RAHUL SELVAN (Tech.manager) 
CALIBRATED BY 		AUTHORIZED SIGNATORY 

# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008. Tamil Nadu. India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

Cert.No : GSR/CC/T202210-03 Page : 04 of 05

### RESULTS OF CALIBRATION

#### RESISTANCE ( $\Omega$ )

Sr.	RANGE	NOMINAL VALUE ( $\Omega$ )	INSTRUMENT READING ( $\Omega$ )	DEVIATION ( $\Omega$ )	MEASUREMENT UNCERTAINTY $\pm \Omega$
1	200 $\Omega$	10.00	10.0	0.01	0.088
		50.00	50.03	0.03	0.088
		100.00	99.99	-0.01	0.088
		200.00	199.97	-0.03	0.088
2	2 K $\Omega$	0.20	0.3	0.10	0.12
		0.50	0.5	0.00	0.12
		1.00	1.0	0.00	0.12
		2.00	1.7	-0.30	0.12
3	20 K $\Omega$	1.00	1.1	0.10	0.175
		5.00	5.0	0.00	0.175
		10.00	10.0	0.00	0.175
		20.00	20.0	0.00	0.175
4	200 K $\Omega$	10.00	9.9	-0.10	0.204
		50.00	49.7	-0.30	0.204
		100.00	99.5	-0.50	0.204
		200.00	199.3	-0.70	0.204
5	2 M $\Omega$	0.10	0.1	0.00	0.26
		0.50	0.5	0.00	0.26
		1.00	1.0	0.00	0.26
		2.00	1.9	-0.10	0.26

G.MUTHURAJ (Calibration Engineer)	PRINCIPAL PSN COLLEGE OF ENGINEERING & TECHNOLOGY MELATHEDIYOOR, PALAYAMKOTTAI TALUK TIRUNELVELI DIST. - 627 152.	C. RAHUL SELVAN (Tech.manager)
CALIBRATED BY	COLLEGE OF ENGINEERING & TECHNOLOGY TIRUNELVELI DIST. 627 152 * MELATHEDIYOOR *	AUTHORIZED SIGNATORY

# GENERAL SCIENTIFIC RESEARCH LABORATORY

## सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008. Tamil Nadu. India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

### CALIBRATION CERTIFICATE

Cert.No : GSR/CC/T202210-03 Page : 05 of 05

#### USED UNCERTAINTY FORMULA

##### TYPE 'A' EVALUTION

$$S^2(T_i) = \frac{1}{n-1} \sum_{i=1}^n (T_i - \bar{T})^2$$

$T_i$  = Ten Measurement of DUC

n = number of reading

##### TYPE 'B' EVALUTION

Uncertainty of master instrument

$$Ub_1 = a/k$$

Uncertainty of standard instrument

$$Ub_2 = a/k$$

Resolution of DUC



$$Ub_3 = a/\sqrt{3}$$

The Estimated Uncertainty to be associated with the result is calculated at a confidence level of approximately 95%.

(Coverage Factor = 2)

#### REMARKS/DEVIATIONS IF ANY

1. The recalibration interval should be determined based on the user's requirements.
2. The user should determine the suitability of the instrument for its intended use.
3. The results stated in this certificate relate only to the item calibrated.
4. The item was received in good condition.
5. The calibration points are taken as per customer requirement.

G.MUTHURAJ (Calibration Engineer)		C. RAHUL SELVAN (Tech.manager)
<b>PRINCIPAL</b> <b>PSN COLLEGE OF ENGINEERING &amp; TECHNOLOGY</b> <b>MELATHEDIOOR, PALAYAMKOTTAI TALUK</b> <b>TIRUNELVELI DIST. - 627 152.</b>		
<b>AUTHORIZED SIGNATORY</b>		
CALIBRATED BY		



# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला

101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008, Tamil Nadu, India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

Cert. No	:	GSR/CC/T202210-04	Page	:	01 of 02
Customer	:	M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY.,			
Address	:	Melathediyoor, Tirunelveli - 627152.			
Date of Received	:	20-Jan-22	Next Due Date	:	19-Jan-23
Date of Calibrate	:	20-Jan-22	Issue Date	:	21-Jan-22
<b>DESCRIPTION &amp; IDENTIFICATION OF INSTRUMENTS</b>					
Instrument Name	:	DUAL REGULATED POWER SUPPLY			
Manufacturer	:	---	Instrument ID No	:	PSNCET/EEE/RPS/01
Model Number	:	302 D	Range	:	0 to 30 V / 0 to 2 A
Location	:	ELECTRICAL DEPARTMENT	Resolution	:	0.1 V / 0.01 A
<b>ENVIRONMENTAL CONDITIONS</b>					
Ambient Temperature	:	28.6 °C	Relative Humidity	:	49.6 %r.h
<b>METHOD OF CALIBRATION</b>					
GSR LAB organisation and practices are derived from ISO/IEC 17025:2017(E). It therefore meets the relevant requirements of ISO 9001:2008(E) when acting as the supplier providing calibration result. The described instrument has been calibrated at GENERAL SCIENTIFIC RESEARCH LABORATORY under the ambient conditions stated above					
<b>STANDARD INSTRUMENT USED</b>					
INSTRUMENT NAME	SL.NO/ID.NO	CAL.DATE	DU DATE	TRACEABILITY	
6 1/2 DIGITAL MULTIMETER	TW00026191	30-Jul-21	29-Jul-22	MKS	
HIGH VOLTAGE TESTER	GSR/EMI/03	04-Sep-21	03-Sep-22	MESO	
MULTIPROCESS CALIBRATOR	HT160100059	30-Jul-21	29-Jul-22	MKS	
<b>TRACEABILITY OF STANDARDS</b>					
The standard used for calibration are traceable to national standard					

MUTHURAJ.G  
(Calibration Engineer)

G. Muthuraj



C. RAHUL SELVAN  
(Tech.manager)

Rahul Selvan

PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.

# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008. Tamil Nadu. India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

Cert.No : GSR/CC/T202210-04 Page : 02 of 02

### RESULTS OF CALIBRATION

#### VOLTAGE VALUE :

Sr.	RANGE	NOMINAL VALUE Volt	INSTRUMENT READING Volt	DEVIATION Volt	MEASUREMENT UNCERTAINTY ± (W)
1	0-30 Volt	10.03	10.0	-0.03	0.575
2	0-30 Volt	20.05	20.0	-0.05	0.575
3	0-30 Volt	30.07	30.0	-0.07	0.575

#### CURRENT VALUE :

Sr.	RANGE	NOMINAL VALUE Amps	INSTRUMENT READING Amps	DEVIATION Amps	MEASUREMENT UNCERTAINTY ± (W)
1	0-2 A	1.001	1.00	-0.001	0.575
2	0-2 A	1.505	1.50	-0.005	0.575
3	0-2 A	2.007	2.00	-0.007	0.575

### REMARKS/DEVIATIONS IF ANY

1. The recalibration interval should be determined based on the user's requirements.
2. The user should determine the suitability of the instrument for its intended use.
3. The results stated in this certificate relate only to the item calibrated.
4. The item was received in good condition.
5. The calibration points are taken as per customer requirement.

MUTHURAJ.G

(Calibration Engineer)

C. RAHUL SELVAN

(Tech. manager)

CALIBRATED BY



PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152 AUTHORIZED SIGNATORY

# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008, Tamil Nadu, India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

CERTIFICATE NO: GSR/CC/T202210-05		Page No:1 of 1			
<b>Customer Name &amp; Address :</b>  M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY, Melathediyoor, Tirunelveli - 627152.		Receipt Date : 20-Jan-22			
Calibration Date : 20-Jan-22	Calibration Due : 19-Jan-23	Issue Date : 21-Jan-22			
<b>Details of Device Under Calibration (DUC)</b>					
Description : AC AMMETER	Identification No : PSNCET/EEE/AM/02	Range : 0 to 20 A			
Make : MECO-V	Least Count : 0.1 A	Model : --	Location : Electrical Department.		
SI.No : 67415	DUC Condition : SATISFACTORY				
<b>Environmental Conditions</b>					
Environmental Details	Temperature: 27.8°C	Relative Humidity	61% Rh		
<b>Standard Operating Procedure Details</b>					
Calibration Procedure No	SOP-T-01	Calibration done at	SITE		
<b>Reference Standards Details</b>					
S.No	Description	Make/ SI No:	Certificate No	Validity	
1	6 1/2 DIGITAL MULTIMETER	TW00026191	MKS/ET/21-22/205-01	29-Jul-22	
2	MULTIPROCESS CALIBRATOR	HT160100059	MKS/ET/21-22/205-02	29-Jul-22	
<b>Calibration Result</b>					
S.No.	STANDARD INSTRUMENTS READINGS	DEVICE UNDER CALIBRATION READINGS	DEVIATION	EXPANDED UNCERTAINTY ( $\pm$ )	STATUS
	A	A	A	A	
1	0.00	0.0	0.00	0.57	PASS
2	2.00	2.0	0.00	0.57	PASS
3	4.97	5.0	-0.03	0.57	PASS
4	9.95	10.0	-0.05	0.57	PASS
5	14.93	15.0	-0.07	0.57	PASS
6	19.92	20.0	-0.08	0.57	PASS
<b>TRACEABILITY OF STANDARDS</b>					
The standard used for calibration are traceable to national standard					

G.MUTHURAJ (Calibration Engineer)  CALIBRATED BY  C. Muthuraj		 PRINCIPAL PSN COLLEGE OF ENGINEERING & TECHNOLOGY MELATHEDIYOOR, PALAYAMKOTTAI TALUK AUTHORIZED SIGNATORY R. RAHUL SELVAN (Tech.manager)  R. Rahul Selvan
--	--	--

# GENERAL SCIENTIFIC RESEARCH LABORATORY



## सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला

101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008, Tamil Nadu, India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

### CALIBRATION CERTIFICATE

CERTIFICATE NO: GSR/CC/T202210-06		Page No: 1 of 1			
<b>Customer Name &amp; Address :</b> M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY,, Melathediyoor, Tirunelveli - 627152.		Receipt Date : 20-Jan-22 Calibration Date : 20-Jan-22 Calibration Due : 19-Jan-23 Issue Date : 21-Jan-22 DUC Condition : SATISFACTORY			
Details of Device Under Calibration (DUC)					
Description : DC AMMETER	Identification No : PSNCET/ECE/AM/01	Output Range : 0 to 50 mA	Least Count : 1 mA		
Make : OXFORD	Location : ECE Department	Model : MR-100	SI.No : ---		
Environmental Conditions					
Environmental Details	Temperature: 25.8°C	Relative Humidity	61% Rh		
Standard Operating Procedure Details					
Calibration Procedure No	SOP-E-04	Calibration done at	SITE		
Reference Standards Details					
S.No	Description	Make/ SI No:	Certificate No	Validity	
1	6 1/2 DIGITAL MULTIMETER	TW00026191	MKS/ET/21-22/205-01	29-Jul-22	
2	MULTIPROCESS CALIBRATOR	HT160100059	MKS/ET/21-22/205-02	29-Jul-22	
Calibration Result					
S.No.	STANDARD INSTRUMENTS READINGS	DUC VALUE	DEVIATION	EXPANDED UNCERTAINTY ( $\pm$ )	STATUS
	mA	mA	mA	mA	
1	10.24	10	0.24	0.68	PASS
2	20.45	20	0.45	0.68	PASS
3	30.58	30	0.58	0.68	PASS
4	40.81	40	0.61	0.68	PASS
5	50.92	50	0.92	0.68	PASS
TRACEABILITY OF STANDARDS					
The standard used for calibration are traceable to national standard					

G.MUTHURAJ  
(Calibration Engineer)

CALIBRATED BY



C. RAHUL SELVAN  
(Tech.manager)

AUTHORIZED SIGNATORY

PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. 627 152

# GENERAL SCIENTIFIC RESEARCH LABORATORY



सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला

101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar.  
Tuticorin - 628008. Tamil Nadu, India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

CERTIFICATE NO: GSR/CC/T202210-07		Page No:1 of 1			
<b>Customer Name &amp; Address :</b>  M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY., Melathediyoor, Tirunelveli - 627152.		Receipt Date : 20-Jan-22			
		Calibration Date : 20-Jan-22			
		Calibration Due : 19-Jan-23			
		Issue Date : 21-Jan-22			
		DUC Condition : SATISFACTORY			
<b>Details of Device Under Calibration (DUC)</b>					
Description : DC AMMETER	Identification No : PSNCET/ECE/AM/02				
Make : LABS	Output Range : 0 to 200 $\mu$ A				
Model : MO-65	Least Count : 5 $\mu$ A				
SI.No : —	Location : ECE Department				
<b>Environmental Conditions</b>					
Environmental Details	Temperature: 25.8° C	Relative Humidity	61% Rh		
<b>Standard Operating Procedure Details</b>					
Calibration Procedure No	SOP-E-04	Calibration done at	SITE		
<b>Reference Standards Details</b>					
S.No	Description	Make/ SI No:	Certificate No	Validity	
1	6 1/2 DIGITAL MULTIMETER	TW00026191	MKS/ET/21-22/205-01	29-Jul-22	
2	MULTIPROCESS CALIBRATOR	HT160100059	MKS/ET/21-22/205-02	29-Jul-22	
<b>Calibration Result</b>					
S.No.	STANDARD INSTRUMENTS READINGS	DUC VALUE	DEVIATION	EXPANDED UNCERTAINTY ( $\pm$ )	STATUS
	$\mu$ A	$\mu$ A	$\mu$ A	$\mu$ A	
1	25.11	25	0.11	2.91	PASS
2	50.71	50	0.71	2.91	PASS
3	100.95	100	0.95	2.91	PASS
4	151.17	150	1.17	2.91	PASS
5	201.31	200	1.31	2.91	PASS
<b>TRACEABILITY OF STANDARDS</b>					
The standard used for calibration are traceable to national standard					

G.MUTHURAJ  
(Calibration Engineer)

CALIBRATED BY



PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. 627152

C. RAHUL SELVAN  
(Tech.manager)

AUTHORIZED SIGNATORY

# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008. Tamil Nadu, India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

CERTIFICATE NO: GSR/CC/T202210-08		Page No:1 of 1			
<b>Customer Name &amp; Address :</b>  M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY., Melathediyoor, Tirunelveli - 627152.		Receipt Date : 20-Jan-22			
Calibration Date : 20-Jan-22	Calibration Due : 19-Jan-23	Issue Date : 21-Jan-22			
<b>Details of Device Under Calibration (DUC)</b>					
Description : DC VOLTMETER	Identification No : PSNCET/ECE/VM/01	Range : 0 to 1 VDC			
Make : OXFORD	Least Count : 0.02 VDC	Location : ECE Department.			
Model : MR-100	DUC Condition : SATISFACTORY				
<b>Environmental Conditions</b>					
Environmental Details	Temperature: 27.8° C	Relative Humidity	61% Rh		
<b>Standard Operating Procedure Details</b>					
Calibration Procedure No	SOP-T-01	Calibration done at	SITE		
<b>Reference Standards Details</b>					
S.No	Description	Make/ SI No:	Certificate No	Validity	
1	MULTIPROCESS CALIBRATOR	HT160100059	MKS/ET/21-22/205-02	29-Jul-22	
<b>Calibration Result</b>					
S.No.	STANDARD INSTRUMENTS READINGS	DEVICE UNDER CALIBRATION READINGS	DEVIATION	EXPANDED UNCERTAINTY ( $\pm$ )	STATUS
	VDC	VDC	VDC	VDC	
1	0.00	0.00	0.00	0.57	PASS
2	0.20	0.20	0.00	0.57	PASS
3	0.40	0.40	0.00	0.57	PASS
4	0.61	0.60	0.01	0.57	PASS
5	0.81	0.80	0.01	0.57	PASS
6	1.02	1.00	0.02	0.57	PASS
<b>TRACEABILITY OF STANDARDS</b>					
The standard used for calibration are traceable to national standard					

G.MUTHURAJ (Calibration Engineer)  CALIBRATED BY  G. Muthuraj		 PRINCIPAL PSN COLLEGE OF ENGINEERING & TECHNOLOGY MELATHEDIYOOR, PALAYAMKOTTAI TALUK TIRUNELVELI DIST. - 627 152.	C. RAHUL SELVAN (Tech.manager)  AUTHORIZED SIGNATORY  Rahul Selvan
--	--	--	---

# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008. Tamil Nadu. India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

CERTIFICATE NO: GSR/CC/T202210-09		Page No: 1 of 1			
<b>Customer Name &amp; Address :</b>					
M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY., Melathediyoor, Tirunelveli - 627152.		Receipt Date	: 20-Jan-22		
		Calibration Date	: 20-Jan-22		
		Calibration Due	: 19-Jan-23		
		Issue Date	: 21-Jan-22		
<b>Details of Device Under Calibration (DUC)</b>					
Description	DC VOLTMETER	Identification No	: PSNCET/ECE/VM/02		
Make	LABS	Range	: 0 to 15 VDC		
Model	MO-65	Least Count	: 0.25 VDC		
SI.No	---	Location	: ECE Department.		
		DUC Condition	: SATISFACTORY		
<b>Environmental Conditions</b>					
Environmental Details	Temperature: 27.8°C	Relative Humidity	: 61% Rh		
<b>Standard Operating Procedure Details</b>					
Calibration Procedure No	SOP-T-01	Calibration done at	SITE		
<b>Reference Standards Details</b>					
S.No	Description	Make/ SI No:	Certificate No	Validity	
1	6 1/2 DIGITAL MULTIMETER	TW00026191	MKS/ET/21-22/205-01	29-Jul-22	
2	MULTIPROCESS CALIBRATOR	HT160100059	MKS/ET/21-22/205-02	29-Jul-22	
<b>Calibration Result</b>					
S.No.	STANDARD INSTRUMENTS READINGS	DEVICE UNDER CALIBRATION READINGS	DEVIATION	EXPANDED UNCERTAINTY ( $\pm$ )	STATUS
	VDC	VDC	VDC	VDC	
1	0.00	0.00	0.00	0.58	PASS
2	3.07	3.00	0.07	0.58	PASS
3	6.15	6.00	0.15	0.58	PASS
4	9.17	9.00	0.17	0.58	PASS
5	12.21	12.00	0.21	0.58	PASS
6	15.24	15.00	0.24	0.58	PASS
<b>TRACEABILITY OF STANDARDS</b>					
The standard used for calibration are traceable to national standard					

G.MUTHURAJ  
(Calibration Engineer)

CALIBRATED BY



C. RAHUL SELVAN  
(Tech.manager)

*Rahul Selvan*  
PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. 627152  
*Rahul Selvan*  
AUTHORIZED SIGNATORY

# GENERAL SCIENTIFIC RESEARCH LABORATORY



सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला

101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008, Tamil Nadu, India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

CERTIFICATE NO: GSR/CC/T202210-10		Page No: 1 of 1			
<b>Customer Name &amp; Address :</b>  M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY, Melathediyoor, Tirunelveli - 627152.		Receipt Date : 20-Jan-22			
		Calibration Date : 20-Jan-22			
		Calibration Due : 19-Jan-23			
		Issue Date : 21-Jan-22			
		DUC Condition : SATISFACTORY			
<b>Details of Device Under Calibration (DUC)</b>					
Description : DC AMMETER					
Make : OXFORD	Identification No : PSNCET/ECE/AM/03				
Model : MR-100	Output Range : 0 to 600 mA				
SI.No : --	Least Count : 10 mA				
Location : ECE Department					
<b>Environmental Conditions</b>					
Environmental Details	Temperature: 25.8° C	Relative Humidity	61% Rh		
<b>Standard Operating Procedure Details</b>					
Calibration Procedure No	SOP-E-04	Calibration done at	SITE		
<b>Reference Standards Details</b>					
S.No	Description	Make/ SI No:	Certificate No	Validity	
1	6 1/2 DIGITAL MULTIMETER	TW00026191	MKS/ET/21-22/205-01	29-Jul-22	
2	MULTIPROCESS CALIBRATOR	HT160100059	MKS/ET/21-22/205-02	29-Jul-22	
<b>Calibration Result</b>					
S.No.	STANDARD INSTRUMENTS READINGS	DUC VALUE	DEVIATION	EXPANDED UNCERTAINTY ( $\pm$ )	STATUS
	mA	mA	mA	mA	
1	100.17	100	0.17	5.78	PASS
2	200.71	200	0.71	5.78	PASS
3	301.11	300	1.11	5.78	PASS
4	401.54	400	1.54	5.78	PASS
5	601.85	600	1.85	5.78	PASS
<b>TRACEABILITY OF STANDARDS</b>					
The standard used for calibration are traceable to national standard					

G.MUTHURAJ  
(Calibration Engineer)

CALIBRATED BY



C. RAHUL SELVAN  
(Tech.manager)

AUTHORIZED SIGNATORY

PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.

# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008, Tamil Nadu, India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

CERTIFICATE NO: GSR/CC/T202210-11		Page No:1 of 2	
Receipt Date	: 20-Jan-22		
Calibration Date	: 20-Jan-22		
Calibration Due	: 19-Jan-23		
Issue Date	: 21-Jan-22		
<b>Customer Name &amp; Address:</b> M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY, Melathediyoor, Madathur, Tirunelveli - 627152.			
<b>Details of Device Under Calibration (DUC)</b>			
Description : :	SCREW GAUGE	Identification No	: PSNCET/MECH/SG/01
Make :	Mitutoyo	Range	: 0 to 25 mm
Model :	—	Least Count	: 0.01 mm
SI.No	: 103-137	Location	: MECHANICAL & METROLOGY
DUC Condition	: Satisfactory		
<b>Environmental Conditions</b>			
Environmental Details	Temperature: 28.5° C	Relative Humidity	51% Rh
<b>Standard Operating Procedure Details</b>			
Calibration Procedure No	SOP-M-10	Calibration done at	SITE
<b>Reference Document Details</b>			
Reference Document	Based on TS-0051		
<b>Reference Standards Details</b>			
S.No	Description	Make/ SI No:	Certificate By
1	SLIP GAUGE SET	GSR/DMI/01	Exquisite
<b>TRACEABILITY OF STANDARDS</b>			
The standard used for calibration are traceable to national standard			

MUTHURAJ.G  
(Calibration Engineer)

CALIBRATED BY



C. RAHUL SELVAN  
(Tech.manager)

Rahul Selvan  
AUTHORIZED SIGNATORY

PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI - 627 152

# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008, Tamil Nadu, India.


E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

CERTIFICATE NO: GSR/CC/T202210-11

Page No:2 of 2

### DIAGRAM OF MICROMETER



### CALIBRATION RESULTS

S.No.	STANDARD INSTRUMENTS READINGS	DEVICE UNDER CALIBRATION READINGS	DEVIATION	EXPANDED UNCERTAINTY ( $\pm$ )	STATUS
	mm	mm	mm	mm	
1	0.500	0.50	0.000	0.032	PASS
2	5.000	5.01	0.010	0.032	PASS
3	10.000	9.99	-0.010	0.032	PASS
4	15.000	15.00	0.000	0.032	PASS
5	20.000	19.99	-0.010	0.032	PASS
6	25.000	24.99	-0.010	0.032	PASS

### REMARKS

- 1.The above mentioned device under calibration was calibrated at SITE.
2. The calibration points are taken as per customer requirement.
- 3.The user should determine the suitability of the instrument for its intended use.
- 4.The recalibration interval should be determined on the user requirement.
5. The item was received in good condition.
- 6.The results stated in this certificate relate only to the item calibrated.
- 7.This Calibration certificate shall not be reproduced except in full, without written approval of the laboratory.
- 8.Any correction / Modification in this calibration report kindly inform within 30 days.
- 9.The indicated uncertainties are expanded uncertainty estimated for a confidence level of approximately 95% for a coverage factor k=2.00

MUTHURAJ.G  
(Calibration Engineer)

CALIBRATED BY



PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.

C. RAHUL SELVAN  
(Tech.manager)

AUTHORIZED SIGNATORY

# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008, Tamil Nadu, India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

Cert. No	:	GSR/CC/T202210-12	Page	:	01 of 03
Customer	:	M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY.,			
Address	:	Melathediyoor, Tirunelveli - 627152.			
Received Date	:	20-Jan-22	Next Due Date	:	19-Jan-23
Calibration Date	:	20-Jan-22	Issue Date	:	21-Jan-22

### DESCRIPTION & IDENTIFICATION OF INSTRUMENTS

Instrument Name	:	<u>ANALOG VERNIER CALIPER</u>		
Manufacturer	:	YAMMAYO	SI Number	:
Id Number	:	PSNCET/MECH/AVC/01	Dial Range	:
Location	:	Mech&Metrology	L.C	:

### ENVIRONMENTAL CONDITIONS

Ambient Temperature :	20.5°C	Relative Humidity	:	58 %r.h
-----------------------	--------	-------------------	---	---------

### METHOD OF CALIBRATION

GSR LAB organisation and practices are derived from ISO/IEC 17025:2017(E). when acting as the supplier providing calibration result. The described instrument has been calibrated at GENERAL SCIENTIFIC RESEARCH LABORATORY under the ambient conditions stated above

### STANDARD INSTRUMENT USED

INSTRUMENT NAME	SL.NO/ID.NO	CAL.DATE	DUE DATE	TRACEABILITY
SLIP GAUGE SET	GSR/DMI/01	04-Sep-21	03-Sep-22	EXQUISITE

### TRACEABILITY OF STANDARDS

The standard used for calibration are traceable to national standard

MUTHURAJ.G  
(Calibration Engineer)

CALIBRATED BY



C. RAHUL SELVAN  
(Tech.manager)

PRINCIPAL AUTHORIZED SIGNATORY

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST - 627 152

# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008. Tamil Nadu, India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

Cert.No : GSR/CC/T202210-12 Page : 02 of 03

### RESULTS OF CALIBRATION

#### CALIBRATION OF EXTERNAL JAWS

Sr.	NOMINAL VALUE (mm)	INSTRUMENT READING (mm)	DEVIATION (mm)	MEASUREMENT UNCERTAINTY $\pm$ (mm)
1	0.50	0.50	0.00	0.0019
2	50.00	50.00	0.00	0.0019
3	100.00	100.00	0.00	0.0019
4	150.00	150.00	0.00	0.0019
5	200.00	200.00	0.00	0.0019
6	300.00	300.02	0.02	0.0019

#### CALIBRATION OF INTERNAL JAWS

Sr.	NOMINAL VALUE (mm)	INSTRUMENT READING (mm)	DEVIATION (mm)	MEASUREMENT UNCERTAINTY $\pm$ (mm)
1	0.50	0.50	0.00	0.0019
2	50.00	50.00	0.00	0.0019
3	100.00	100.00	0.00	0.0019
4	150.00	150.00	0.00	0.0019
5	200.00	200.00	0.00	0.0019
6	300.00	300.02	0.02	0.0019

$$S^2(T_i) = \frac{1}{n-1} \sum_{i=1}^n (T_i - \bar{T})^2$$

Uncertainty of master instrument

$$U_{b1} = a/k$$

Uncertainty of standard instrument

$$U_{b2} = a/k$$

Resolution of DUC

$$U_{b3} = a/\sqrt{3}$$

The Estimated Uncertainty to be associated with the result is calculated at a confidence level of approximately 95%. (K=2)

MUTHURAJ.G

(Calibration Engineer)

CALIBRATED BY




C. RAHUL SELVAN

(Tech.manager)



PRINCIPAL

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DISTRICT - 627 152



# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008, Tamil Nadu, India.


E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

Cert.No : GSR/CC/T202210-12

Page : 03 of 03

### DIAGRAM OF VERNIER CALIPER



### RESULTS OF CALIBRATION

#### CALIBRATION OF DEPTH MEASURING BLADE

Sr.	NOMINAL VALUE (mm)	INSTRUMENT READING (mm)	DEVIATION (mm)	MEASUREMENT UNCERTAINTY(mm)
1	0.50	0.50	0.00	0.0019
2	25.00	25.00	0.00	0.0019
3	50.00	50.00	0.00	0.0019
4	100.00	100.00	0.00	0.0019
5	150.00	150.00	0.00	0.0019
6	200.00	200.00	0.00	0.0019
7	250.00	250.02	0.02	0.0019
8	300.00	300.02	0.02	0.0019

### REMARKS/DEVIATIONS IF ANY

- The recalibration interval should be determined based on the user's requirements.
- The user should determine the suitability of the instrument for its intended use.
- The results stated in this certificate relate only to the item calibrated.
- The item was received in good condition.
- The calibration points are taken as per customer requirement.

MUTHURAJ.G  
(Calibration Engineer)

CALIBRATED BY



C. RAHUL SELVAN  
(Tech.manager)

AUTHORIZED SIGNATORY

PRINCIPAL

PSN COLLEGE OF ENGINEERING & TECHNOLOGY

MR. THIRUMALAIDHARAI, MAMKOTTAI TALUK

# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008. Tamil Nadu. India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

CERTIFICATE NO: GSR/CC/T202210-13		Page No: 1 of 1			
<b>Customer Name &amp; Address :</b> <b>M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY,</b> Melathediyoor, Tirunelveli - 627152.		Receipt Date : 20-Jan-22	Calibration Date : 20-Jan-22		
		Calibration Due : 19-Jan-23	Issue Date : 21-Jan-22		
<b>Details of Device Under Calibration (DUC)</b>					
Description : GLASS THERMOMETER	Identification No : PSNCET/MECH/GTM/01	Range : -10 to 110 °C	Least Count : 1 °C		
Make : DIMPLE	Location : MECHANICAL & METROLOGY	SI.No : —	DUC Condition : SATISFACTORY		
<b>Environmental Conditions</b>					
Environmental Details	Temperature: 25.8° C	Relative Humidity	51% Rh		
<b>Standard Operating Procedure Details</b>					
Calibration Procedure No	SOP-T-08	Calibration done at	SITE		
<b>Reference Standards Details</b>					
S.No	Description	Make/ SI No:	Certificate No	Validity	
1	RTD SENSOR	948	JRPM-CCTR-THER-2021-0351	18-03-2022	
2	DIGITAL MULTIMETER	TW00026191	MKS/ET/21-22/205-01	29-07-2022	
<b>Calibration Result</b>					
S.No.	STANDARD INSTRUMENTS READINGS	DEVICE UNDER CALIBRATION READINGS	DEVIATION	EXPANDED UNCERTAINTY (±)	STATUS
	°C	°C	°C	°C	
1	-9.71	-10.0	-0.29	0.81	PASS
2	0.35	0.0	-0.35	0.81	PASS
3	40.41	40.0	-0.41	0.81	PASS
4	80.47	80.0	-0.47	0.81	PASS
5	110.55	110.0	-0.55	0.81	PASS
<b>TRACEABILITY OF STANDARDS</b>					
The standard used for calibration are traceable to national standard					



# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008, Tamil Nadu, India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

Cert. No	:	GSR/CC/T202210-14	Page	:	01 of 02
Customer	:	M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY.,			
Address	:	Melathediyoor, Tirunelveli - 627152.			
Received Date	:	20-Jan-22	Next Due Date	:	19-Jan-23
Calibration Date	:	20-Jan-22	Issue Date	:	21-Jan-22

### DESCRIPTION & IDENTIFICATION OF INSTRUMENTS

Instrument Name	:	<u>HEIGHT GAUGE</u>		
Manufacturer	:	Mitutoyo	SI Number	: 10216283
Id Number	:	PSNCET/MECH/GH/01	Dial Range	: 0 to 300 mm
Location	:	Mech&Metrology	L.C	: 0.02 mm

### ENVIRONMENTAL CONDITIONS

Ambient Temperature :	20.5°C	Relative Humidity	:	58 %r.h
-----------------------	--------	-------------------	---	---------

### METHOD OF CALIBRATION

GSR LAB organisation and practices are derived from ISO/IEC 17025:2017(E). when acting as the supplier providing calibration result. The described instrument has been calibrated at GENERAL SCIENTIFIC RESEARCH LABORATORY under the ambient conditions stated above

### STANDARD INSTRUMENT USED

INSTRUMENT NAME	SL.NO/ID.NO	CAL.DATE	DUE DATE	TRACEABILITY
SLIP GAUGE SET	GSR/DMI/01	04-Sep-21	03-Sep-22	EXQUISITE

### TRACEABILITY OF STANDARDS

The standard used for calibration are traceable to national standard

MUTHURAJ.G

(Calibration Engineer)

CALIBRATED BY



C. RAHUL SELVAN

(Tech.manager)

PRINCIPAL AUTHORIZED SIGNATORY

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.

# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008, Tamil Nadu, India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

Cert.No : GSR/CC/T202210-14

Page : 02 of 02

### DIAGRAM OF HEIGHT GAUGE



### RESULTS OF CALIBRATION

#### CALIBRATION OF DEPTH MEASURING BLADE

Sr.	NOMINAL VALUE (mm)	INSTRUMENT READING (mm)	DEVIATION (mm)	MEASUREMENT UNCERTAINTY(mm)
1	0.50	0.50	0.00	0.0019
2	25.00	25.00	0.00	0.0019
3	50.00	50.00	0.00	0.0019
4	100.00	100.00	0.00	0.0019
5	150.00	150.02	0.02	0.0019
6	200.00	200.00	0.00	0.0019
7	250.00	250.00	0.00	0.0019
8	300.00	300.02	0.02	0.0019

### REMARKS/DEVIATIONS IF ANY

- The recalibration interval should be determined based on the user's requirements.
- The user should determine the suitability of the instrument for its intended use.
- The results stated in this certificate relate only to the item calibrated.
- The item was received in good condition.
- The calibration points are taken as per customer requirement.

MUTHURAJ.G  
(Calibration Engineer)

CALIBRATED BY



PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI

C. RAHUL SELVAN  
(Tech.manager)

PRINCIPAL

AUTHORIZED SIGNATORY

# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008, Tamil Nadu, India.

E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

Cert. No	: GSR/CC/T202210-15	Page	: 01 of 02	
NABL Doc. No	: NABL-122-01-Doc	NABL LAB ID	: C-1278	
Customer	M/s PSN COLLEGE OF ENGINEERING AND TECHNOLOGY.,			
Address	Melathediyoor, Tirunelveli - 627152.			
Received Date	: 20-Jan-22	Next Due Date	: 19-Jan-23	
Calibration Date	: 20-Jan-22	Issue Date	: 21-Jan-22	
<b>DISCRIPTION &amp; IDENTIFICATION OF INSTRUMENTS</b>				
Instrument Name	: BEVEL PROTRACTOR	Serial No	: 1010138	
Manufacturer	: Aerospace	Range	: 0 to 360°	
Id Number	: PSNCET/MECH/GTM/01	L.C	: 1°	
Location	: MECHANICAL & METROLOGY			
<b>ENVIROMENTAL CONDITIONS</b>				
Ambient Temperature :	20.9 °C	Relative Humidity	: 51.6 %r.h	
<b>METHOD OF CALIBRATION</b>				
GSR LAB organisation and practices are derived from ISO/IEC 17025:2017(E), when acting as the supplier providing calibration result. The described instrument has been calibrated at GENERAL SCIENTIFIC RESEARCH LABORATORY under the ambient conditions stated above				
<b>STANDARD INSTRUMENT USED</b>				
INSTRUMENT NAME	SL.NO/ID.NO	CAL.DATE	DU DATE	TRACEABILITY
SLIP GAUGE SET	GSR/DMI/01	4-Sep-2021	3-Sep-2022	Exquisite
ANGLE GAUGE SET	GSR/DMI/10	4-Sep-2021	3-Sep-2022	Exquisite
<b>TRACEABILITY OF STANDARDS</b>				
The standard used for calibration are traceable to national standard				
Result of calibration last page				



MUTHURAJ.G  
(Calibration Engineer)

C. RAHUL SELVAN  
(Tech.manager)

PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152

# GENERAL SCIENTIFIC RESEARCH LABORATORY

सामान्य वैज्ञानिक अनुसंधान प्रयोगशाला



101, First Floor, Ebenezer Castle,  
3rd Street, Kamaraj Nagar,  
Tuticorin - 628008, Tamil Nadu, India.


E-Mail : sales@gsrlab.in /  
gsrlab01@gmail.com  
Website : http://www.gsrlab.in

## CALIBRATION CERTIFICATE

Cert.No : GSR/CC/T202210-15

Page : 02 of 02

### DIAGRAM OF DEGREE PROTRACTOR



### RESULTS OF CALIBRATION

Sr.	NOMINAL VALUE (DEGREE)	INSTRUMENT READING (DEGREE)	DEVIATION (DEGREE)	MEASURMENT UNCERTAINTY(DEGREE)
1	0.000	0.00	0.000	0.0019
2	90.002	90.00	-0.002	0.0019
3	180.001	180.00	-0.001	0.0019
4	270.002	270.00	-0.002	0.0019
5	360.002	360.00	-0.002	1.0019

### USED UNCERTAINTY FORMULA

#### TYPE 'A' EVALUTION

$$S^2(T_i) = \frac{1}{n-1} \sum_{i=1}^n (T_i - \bar{T})^2$$

$T_i$  = Ten Measurement of DUC

n = number of reading

Uncertainty of master instrument

$$Ub_1 = a/k$$

Uncertainty of standard instrument

$$Ub_2 = a/k$$

Resolution of DUC

$$Ub_3 = a/\sqrt{3}$$


The Estimated Uncertainty to be associated with the result is calculated at a confidence level of approximately 95%. (K=2)

MUTHURAJ.G  
(Calibration Engineer)

CALIBRATED BY




C. RAHUL SELVAN  
(Tech.manager)



PRINCIPAL

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK



24 Hours Customer Support : 9751561183 | Sales / Marketing : 8072486382



# HOUSE KEEPING MAINTENANCE

## PRINCIPAL

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOKK, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.



**HOUSE KEEPING AND MAINTENANCE STOCK  
REGISTER - NOTE**

SL.NO	PRODUCT NAME	PRICE NO	IN STOCK
01	BLEACHING POWDER	4	80
02	DUST BINS	4	110
03	FLOOR CLEANER	5	45
04	Liquid DETERGENT (SOAPOL)	6	90
05	BUCKET	7	80
06	MORAM	8	25
07	MAT	9	60
08	CUSHION MAT	10	10
09	SPRAY BOTTLE	11	05
10	LIFEBOY HAND WASH	12	13
11	HAND SANITIZER	13	25
12	BROOM STICK	14	15
13	MUIN	15	10
14	PHINEYIL	16	30
15	TOILET BRUSH	17	30
16	SOAP STAND	18	20
17	TOWELS	19	25
18	DISHWASH BAR	20	100
19	SPONGE	21	50
20	FACE MASK	22	2000



PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST, 627 152

## 2 BLEACHING POWDER

3

DATE	ITEMS and Work in Place	REQD QTY	ISSUE QTY	BAL	INCHARGE Signer	HOD Signer
08/10/21	P.L Block bathroom cleaning. (men)	80	02	78	S	S
11/10/21	1ST Year Block bathroom cleaning	78	02	76	N	S
13/10/21	P.L Block Women bathroom Cleaning	76	03	73	PL	S
16/10/21	Main block bathroom cleaning women	73	01	72	N	S
21/10/21	BHARATHI HOSTEL bathroom Cleaning	72	10	62	N	S
02/11/21	NARMADHA HOSTEL Cleaning	62	15	47	N	S
12/11/21	Mechanical department bathroom Cleaning	47	05	42	N	S
18/11/21	FEE - 02 block cleaning	42	05	37	N	S
27/11/21	ECE department bathroom Cleaning	37	10	35	N	S
03/12/21	Board room bathroom cleaning	35	01	34	N	S
07/12/21	P.L Block bathroom cleaning	34	02	32	N	S
05/01/22	Main office Cleaning	32	01	31	N	S
07/01/22	1ST year block cleaning	31	05	26	N	S
10/01/22	main block women bathroom Cleaning	26	02	24	N	S
12/01/22	ANCHOR hostel Cleaning work	24	05	19	N	S
16/01/22	Narmadha hostel cleaning work	19	10	09	N	S

~~XX~~

PRINCIPAL

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYUR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. 627 152

## 4 DUST BINS

DATE	Work in Place	RECD QTY	ISSUE QTY	BAL	Incharge Sign	HOD Sign
09/10/21	1ST year Ground floor Labone	110	02	118	NR	fr
11/10/21	P.LN block bathroom ground floor	118	04	114	NR	fr
15/10/21	P.LN Auditorium Hall	114	10	104	NR	fr
18/10/21	BHARATHI Hostel	104	05	109	NR	fr
21/10/21	Main block Ground floor E.O office	109	04	105	NR	fr
23/10/21	Ground floor Physics lab	105	02	103	NR	fr
25/10/21	Narmadha Girls hostel 5th floors	103	10	93	NR	fr
29/10/21	Main office Ground floor	93	05	88	NR	fr
07/11/21	Anchor Hostel 5th floor rooms	88	10	78	NR	fr
11/11/21	Chemistry Lab in Main block	78	03	75	NR	fr
16/11/21	P.S.N Canteen coffee Shop	75	05	70	NR	fr
18/11/21	Marine department Inround floor	70	10	60	NR	fr
27/11/21	Anchor Hostel Ground floor, 5st floor	60	10	50	NR	fr
03/12/21	EEE block Serv floor Lab	50	02	48	NR	fr
07/12/21	CIVIL Department 1st floor	48	07	41	NR	fr
16/12/21	P.S.N MESS	41	03	38	NR	fr
20/12/21	ITAC office	38	02	36	NR	fr

## 5 FLOOR CLEANER

DATE	Work in Place	RECD QTY	ISSUED QTY	BAL	Incharge Sign	HOD Sign
16/10/21	P.LN Block 1st floor, and 2nd floor lab cleaning	45	02	43	NR	fr
18/10/21	Main block E.O office Board Room and ITAC office cleaning	43	03	40	NR	fr
01/11/21	Narmadha Womens hostel 1, 2nd and 3rd floor cleaning	35	10	25	NR	fr
07/11/21	Marine department 1st and Lab cleaning	25	02	23	NR	fr
17/11/21	Vivekanada auditorium Cleaning Physics P.LN Auditorium Cleaning Purpose	23	05	18	NR	fr
05/12/21	P.S.N Cafe cleaning work	18	03	15	NR	fr
08/12/21	P.S.N Canteen cleaning work	15	06	09	NR	fr
17/12/21	Workshop mechanical cleaning work	09	02	07	NR	fr
17/12/21	Computer Lab Cleaning Work	07	03	04	NR	fr



PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIVOR, PALAYAMKOTHI TALUK,  
TIRUNELVELI DIST - 627 152

Date	Work in Place	RECD BY	ISSUED QTY	BALANCE	Exchange SIGN	HOD SIGN	DATE	Work in Place	RECD BY	ISSUED QTY	BALANCE	Exchange SIGN	HOD SIGN
17/10/21	Main office	20	02	18	NO	fr	03/10/21	SOBES control	80	20	60	NO	fr
	Windows screen							all toilets and					
	Wash							classrooms					
27/10/21	E.D office room	18	01	17	NO	fr	07/11/21	Main block Ground	60	15	45	NO	fr
	Window screen							floor all rooms					
	and towels							and bathroom					
13/11/21	Board room screen	17	-02	15	NO	fr	09/11/21	Marine bathroom	45	03	42	NO	fr
	and cleaning												
17/11/21	Computer Lab	15	03	12	NO	fr	07/12/21	Main office	42	02	40	NO	fr
	Screens cleaning							Anchor hostels					
23/11/21	Mechanical Lab	18	-02	10	NO	fr		Central floors and	40	20	20	NO	fr
	Cleaning							bathrooms					
05/12/21	TCS and TCE	10	05	05	NO	fr	11/12/21	Library cleaning	20	05	15	NO	fr
	Lab cotton cloths							work					
	Cleaning												
07/01/22	Dispensary bed	05	05	-05	NO	fr	12/01/22	Bharathi hostel	15	03	12	NO	fr
	Cloth Cleaning							work					



X

PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYODU, PALAYAMEOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.

Date	Work in Place	RECD			ISSUED			Incharge	HOD	Sign	Sign	RECD	ISSUED			Incharge	HOD	Sign
		QTY	QTY	BALANCE	QTY	QTY	BALANCE						QTY	QTY	BALANCE			
02/11/21	I.S.K. year classroom	25	05	20	N.Y.	J.R.	02/11/21	Mechanical		60	10	50	N.Y.	J.R.				
	Entry							department class										
03/11/21	P.I.N. block bath room	20	02	18	N.Y.	J.R.	03/11/21	P.I.N. block I.S.K.	50	15	35	N.Y.	J.R.					
12/11/21	Main office entrance	18	02	16	N.Y.	J.R.	12/11/21	1st and 3rd floor rooms										
27/11/21	CSE department Labs	16	06	10	N.Y.	J.R.	07/01/22	Workshop	35	05	30	N.Y.	J.R.					
05/12/21	E.D. office and board room ens	10	04	06	N.Y.	J.R.	11/01/22	Bharathi hostel	30	10	20	N.Y.	J.R.					
06/12/21	Library	06	08	04	N.Y.	J.R.	11/01/22	Narmadha hostel	20	15	05	N.Y.	J.R.					
10/12/21	Anchor hostel Warden rooms	04	02	02	N.Y.	J.R.												



25

PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIVOUR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. 627 152.

## CUSHION MAT

## SPRAY BOTTLE

Date	Work in Place	RECD ISSUED					Incharge	HOD	RECD ISSUED					Incharge	HOD
		QTY	QTY	BALANCE	SIGN	SIGN			Date	Work in Place	QTY	QTY	BALANCE	SIGN	
03/11/21	P.tu Auditorium Stage Stels	10	04	08	Mr.	Mr.	03/11/21	P.tu bathroom wall	05	01	04	Mr.	Mr.		
07/01/22	Vivekananda Auditorium Stage Stels wise	08	03	05	Mr.	Mr.	07/01/22	Board room bathroom	04	02	02	Mr.	Mr.		
09/01/22	Board Room	05	01	04	Mr.	Mr.									




PRINCIPAL  
S.N.COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEEDYODI, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST - 627 152.

## 12 LIFEBOY HAND WASH

## HAND SANITIZER

13

Date	Work in Place	RECD ISSUED					Encharge	HOD Sign	Date	Work in Place	RECD ISSUED					Encharge	HOD Sign
		QTY	QTY	BAL	Incharge	HOD Sign					QTY	QTY	BAL	Sign	Sign		
05/10/21	I <sup>ST</sup> year block all bathrooms	13	05	08	Mr	John	17/10/21	EEE Classroom and Lab entrance	25	02	23	Mr	Mr	Mr	Mr	Mr	Mr
07/11/21	Mechanical, EEE and ECE DEPT all bathrooms	08	05	03	Mr	John	08/11/21	ECE and LAS Main office Entrance	23	03	20	Mr	Mr	Mr	Mr	Mr	Mr
08/11/21	Main office, and E.D office because bathrooms	03	02	01	Mr	John	11/11/21	P.I. block class Rooms	16	05	11	Mr	Mr	Mr	Mr	Mr	Mr

~~PF~~

PRINCIPAL  
PSM COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIVOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST - 627 152.

Date	Work in Place	RECD	ISSUED	Incharge	HOD	Date	Work in Place	RECD	ISSUED	Incharge	HOD	
		QTY	QTY	BAL	Sign			QTY	QTY	BAL	Sign	Sign
07/11/21	I <sup>ST</sup> year block Ground floor	15	03	12	✓	16/11/21	Block front tank work	10	01	09	M.T.	✓
09/11/21	Main office	12	01	11	✓	16/11/21	Marine department	09	04	05	M.T.	✓
11/11/21	T.A.C. office	11	01	10	✓	05/01/22	E.I.E					
17/11/21	Chemistry Lab	10	02	08	✓	16/01/22	E.D. office	05	02	03	M.T.	✓
19/11/21	Physics Lab	08	03	05	✓							
20/11/21	Work shop General	05	02	03	✓							
05/01/22	E.D. office	03	01	02	✓							
09/01/22	I <sup>ST</sup> year Ground floor	02	02	-	✓							




✓  
F.I.

### PRINCIPAL

P.S.N COLLEGE OF ENGINEERING & TECHNOLOGY  
TIRUNELVELI TIRUVALLUAR ROAD, PALAYAMKOTTAI, TIRUNELVELI DISTRICT - 627 402

Date	Work in Place	RECD ISSUED					Incharge HOD					RECD ISSUED					Incharge HOD				
		QTY	QTY	BAL	Sign	Sign	Date	Work in Place	QTY	QTY	BAL	Sign	Sign	Date	Work in Place	QTY	QTY	BAL	Sign	Sign	
07/10/21	Marine department bathroom	30	02	28	M.	JIN	02/11/21	MBB department	30	02	28	M.	JIN	07/11/21	Vivekanand auditorium	28	01	27	M.	JIN	
09/11/21	mechanical department	28	03	25	M.	JIN	05/01/22	Board room	27	01	26	M.	JIN	07/01/22	P.W auditorium	26	01	25	M.	JIN	
11/10/21	CSE, ECE and EEE department	25	06	19	M.	JIN	11/01/22	E.D office	25	01	24	M.	JIN								



**PRINCIPAL**  
**PSN COLLEGE OF ENGINEERING & TECHNOLOGY**  
**MELATHUR, PALAYAMKOTTAI TALUK**  
**TIRUNELVELI DIST - 621 162**

18

## Soap Stand

Date	Work in Place	RECD ISSUED				Incharge	HOD
		QTY	QTY	BAL	SIGN		
07/01/22	1st year	do	08	18	M.R	X	09/01/22
11/01/22	Computer lab	18	01	17	M.R	X	

## TOWELS

17

Date	Work in Place	RECD ISSUED				Incharge	HOD
		QTY	QTY	BAL	SIGN		
25/01/22	Main office	01	24	M.R	X		

~~✓✓~~

PRINCIPAL

PSH COLLEGE OF ENGINEERING & TECHNOLOGY  
 PALLAVANPUDUR, PALAYARKOTTAI TALUK  
 TIRUNELVELI DISTRICT - 627 152



20

## DISHWASH BAR

Date

RECD  
QTYISSUED  
QTY

BAL

Incharge  
SignHOD  
SIGN

Work in Place

PSN coffee shop

100

10

90

MR

SIN

MESS

90

10

80

MR

X

PSN coffee shop

80

10

70

MR

SIN

MESS

70

10

60

MR

SIN

## SPONSHR

21

RECD  
QTYISSUED  
QTYIncharge  
SignHOD  
SIGN

Date	Work in Place	RECD QTY	ISSUED QTY	BAL	Incharge Sign	Date	Work in Place	RECD QTY	ISSUED QTY	BAL	Incharge Sign	HOD SIGN
05/12/21	PSN coffee shop	100	10	90	MR	07/12/21	1st year HOD	50	04	46	MR	SIN
08/12/21	MESS	90	10	80	MR	08/12/21	Mechanical dept	46	05	41	MR	SIN
07/01/22	PSN coffee shop	80	10	70	MR	11/01/21	EEE dept	41	05	36	MR	SIN
10/01/22	MESS	70	10	60	MR	15/01/21	ECIE dept	36	04	32	MR	SIN
						08/01/22	Main office	32	08	30	MR	SIN
						07/01/22	Board room	30	01	29	MR	SIN
						11/01/22	Main water	29	01	28	MR	SIN

~~PSN~~

**PRINCIPAL**  
 PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
 MELATHREDIYUR, PALAYAMKOTTAI TALUK  
 TIRUNELVELI DIST. - 627 152.

## FACE MASK

Date	Wore in place	REC'D QTY	ISSUED QTY	BAL	Stocks sign	HOD sign
06/01/21	To SOBES debt	2000	100	1900	N	J
07/01/21	To marine debt	1900	800	1700	M	J
02/01/22	To ECE debt	1700	100	1600	M	J
05/01/22	To MBA	1600	100	1500	M	J
07/01/22	To CSE	1500	100	1400	M	J
11/01/22	To EEE	1400	100	1300	M	J
16/01/22	To mechat Auto	1300	800	1100	M	J
17/01/22	To Mechanical	1100	100	1000	N	J



PRINCIPAL  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYODU, PALAIKURTTI TALUK  
TIRUNELVELI DIST. 637 152.



# PRINTER, SCANNER AND COPIER MAINTENANCE

## PRINCIPAL

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYANKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.



Maintenance Register - Printers / Scanners / Copiers

10	Date	Department / Division	Name of the complaint	Parts replaced work done	Done by	HOD sign	Principal sign.
	03/09/21	ED office	Printer - 337 Toner, Drum Problem.	completed	mr.Raja	for ED	X
	03/09/21	Board Room	Printer - 12A Refill (Additional Drum)	completed	mr.Raja	for P.D.A	X
	03/09/21	Sobcs / HOD room	Printer - 88A Refill.	completed	mr.Raja	Mr. Muthu	X
5	26/08/21	ED office	Printer - 337 Toner refilled	completed	Raja	P.D.A	X
	11/11/21	I year	Toner Refill Toner Drum Blade	completed	Raja	✓	Dev.



31/8/21	CSE	HP 1020 Printer Fregher Rolorchanges Tastan fillim Printer Toner Sensor	Compiled Mr. Raja	✓
30/8/21	MBA	12A Toner Refilling Drem & Blake	Compiled Mr. Raja	✓
29/9/21	Solar Lab	88A Toner Refilling	"	✓
27/10/21	Board Room	12A Toner refilling	Compiled Mr. Raja	✓
31/12/21	Main Office	Brother Toner Refilling	PRINCIPAL PSN COLLEGE OF ENGINEERING & TECHNOLOGY MELATHEDIYOR, PALAYAMKOTTAI TALUK TIRUNELVELI DIST. - 627 152.	✓



10 6/12/21 Ed office

Canon Toner

Compiled

Done

11 9/12/21 civil dept

Refilling  
toner cartridge  
laser level

Completed

11.m.

12 18/12/21 ED office

12A Toner  
HP Printer

12A Toner  
Refill

13 22/12/21 COE

12A Toner  
Refilling

Compiled

14 31/12/21 CSE

HP 1020  
Printer  
motor  
Printer  
service

Compiled



~~PRINCIPAL~~  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152



# RO PLANT

# MAINTENANCE

## PRINCIPAL




PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYODU, PALAYANKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.



SNO	DATE	UNIT-I Anchor Hostel RO Plant NATURE OF THIS WORK	AMOUNT SIGN
40	30.12.2021	RO plant full maintenance [carbon, stone, sand, filter, membrane]	20,000 <del>30/12/21</del> <del>✓</del>
41.	27/5/22	RO plant - 20Inch wound Filter - 2 replaced	1300 <del>27/5/22</del>
42.	28/10/22	RO plant - 4 way mcb replaced.	1350 <del>28/10/22</del> <del>✓</del>
43.	9.03.22	R.O Plant - membrane, media , 20 Inch wound Charged	17,000 <del>9.03.22</del> <del>✓</del>

SNO DATE UNIT-II NATURE OF WORK SHIP IN Building RO Plant AMOUNT SIGN

33) 22/01/20	RO filter		16,500	<i>Ar</i>
34) 04/02/20	RO MPS		800	<i>Ar</i>
	· 800			
35) 25/02/20	RO filter		16,500	<i>Ar</i>
	16,500			
36) 05/03/21	Film tech membership		1600	<i>Ar</i>
	1600			
37) 10/03/21	I.R filter		230	<i>Ar</i>
	230			
		X	230	

SNO	Date	Nature of Work	Amount	Sign.
31	28/12/19	Ro Filter 16,500	16500	
32	4/1/20	IR Filter 230	230	
33	29/1/20	Ro Housing 1000	1000	
34	4/2/20	Flim tech membranes 1600	1600	
35	26/2/20	Ro Pump 1600	1600	
36	29/2/20	IR Filter 230	230	
37	25/2/21 <del>25/2/20</del>	Flim tech membrane 1600	1600	

PRINCIPAL  
 PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
 MELATHEDIVOOR, PALLIKKETTAI TALUK  
 TIRUNELVELI - 627 152.

## UNIT IV ladies moste Re place of work

Amount Sign

33.	8/1/20	IR filter	2200	₹230/-
33.	22/1/20	RO plant filter	16,500	₹16,500 ✓
34.	14/2/20	RO Housing + IR filter	1000 230	₹1230 ✓
35.	27/2/20	RO pump	1,600	₹1600/-
36.	6/3/20	Film tech membrane	1,600	₹81,600 ✓
37.	19/2/21	RO SMPS	800	₹800 ✓
38.	16/3/21	RO plant filter Membrane charge	16,500	₹16,500 ✓
40.	27/4/22	RO plant filter charge. ( 2 filters )	1450	₹2900/-
41.	12/5/22	membrane, fiber ad jected	16,000 ✓	₹16,000 ✓

## PRINCIPAL

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
 MELATHEDIYOD, PALAYAMKOTTAI TALUK  
 TIRUNELVELI DIST - 627152

40. 27/4/22 RO plant filter charge.  
 ( 2 filters ) 1450 ₹2900/-

41. 12/5/22 membrane, fiber ad jected 16,000 ✓ ₹16,000 ✓

NO	DATE	NATURE OF WORK	Amount	SL
2.	19.10.22	Filter Change	Rs. 1300	13 13 13  DN 20T
3.	17/11/22	2 filter change.		
4	21/14/23	RO Plant Service (Membrane, sand, stone, carbon changed)	17,180/-	
				<del>✓</del>

**PRINCIPAL**  
 PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
 MELATHURMURUGANALAYAM - OTTAKALU  
 TELANGANA - INDIA - 5027102.

S.NO	DATE	NATURE OF WORK	AMOUNT	STB/M
36.	26/02/21	I.R Filter 230	230	By
37.	18/03/21	Film tech membrane 1,600	1,600	By
38.	12/10/21	40/40 membrane 314, Bal valve 314, CPVC union 2 <sup>nd</sup> filter Service charge	13,000 340 110 900 <hr/> 15,940	By
39.	7/01/21	20 Inlet S Charge	900 + 350 <hr/> 1250	By
40.	11/12/21	PRINCIPAL - PSN COLLEGE OF ENGINEERING & TECHNOLOGY MELATHEDYOGA PATTABADAI SALUK TIRUNELVELI - 627 152 Plumbing, CPVC Spares - ① B - chge - ①	724	X

Bhavathi Hotel RO plant			
41.	23/05/22	Chemical wash 20 inch, wound (2 Nos)	5000 1100 <hr/> 6100
			Done C 23/5/22
42.	09/05/22	Chemical wash, carbon, filter change <del>Ex</del> Total	7000 5000 <hr/> 12,000
			Done T 15/5/22
43.	03/06/2022	Filter change (2 Nos) chemical charge and labour charge	1500 + 450 + 50 <hr/> 2450
			<del>Done</del> Done
44.	16/05/2022	PRINCIPAL PUNJAB COLLEGE OF ENGINEERING & TECHNOLOGY MELA THEEDU OR, PALAYAMKOTTAI TALUK TIRUNELVELI DISTRICT Santwansh vacuum etc.	Rs. 14,600/-
			<del>Done</del> Done 16/5/22
45.	20/05/22	20 inch wound filter (2 Nos) Labour charge	900 + 300  = Rs. 1200/- <del>Ex</del> C
46.	06/01/2023	Membrane, filter, drainage, labour	Rs. 17,000/- <del>Done</del> Done 06/1/23



**PSN** College of Engineering and Technology  
An Autonomous Institution, Affiliated to Anna University  
Approved by AICTE, Accredited by NAAC with A+ Grade


# ELECTRICAL MAINTENANCE




**PRINCIPAL**

PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYODU, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.





S.NO	DATE	MAINTENANCE	AMOUNT
1.	14/10/22	Purchase materials	Rs. 7105.00
2.	25/10/22	PVC Door Work	Rs. 1308.00
3.	28/10/22	Electrical Materials purchase	Rs. 5695.00
4.	29/10/22	purchase electrical & plumbing for Anchor Hostel  <del>27</del> Bharathi Hostel Men's Verandah and Anchor Hostel (Cooking)	Rs. 7213.00
5.	26/10/22	Anchor Hostel electrical work	12 x 608L
	27/10/22		6 x 1300
	28/10/22		Rs. 7800/-
	29/10/22	Labour Salary details.	
6.	29/10/22	Brush and Turpentine oil for cot painting in Girls hostel	Rs. 410.00
7.	1/11/22	Anchor Hostel Toilet cleaning 30.10.22. Chigerton P.C.F.K	Rs. 2500/-
8	02/11/22	Paint materials for Anchor & Girls hostel	



S.NO	DATE	MAINTENANCE	AMOUNT
9	29/5/22	Paint brush & Emery sheet for Anchor hostel purchase material	Rs 1200/- ✓
10	30/5/22	Fan Winding work in Anchor hostel	Rs 6900/-
11	05/6/22	Electrical Work in the Anchor's Girls & street light	Rs 6500/-
12	31/5/22	COT Painting work in girl's hostel	Rs. 3520/-
13	31/5/22	COT Painting work in girl's hostel	Rs. 6270/-
14	31/5/22	purchased western tank for bath room work in the Anchor Hostel	Rs 6700/-
15	16/6/22	<del>Mr. Mani &amp; Co. 12 nos. of new PVC</del> <del>PIPELINE &amp; METER CO. LTD.</del> <del>VELAIYATHDEIVOOIR COLLEGE OF ENGINEERING &amp; TECHNOLOGY, BHARATHI HOSTEL</del> room cleaning work at Bharathi Hostel cheque from TEC(I) a/c	Rs. 20400/-
16	15/6/22	room cleaning work cheque from TEC(I) a/c	Rs. 65,530/-
17	18/6/22	purchased Inverter and Battery for Bharathi Hostel Hrs cheque from fire & safety a/c	Rs. 15,000/-
18	19/6/22	purchased electrical & plumbing material for girl's hostel Cheque from TEC(I) a/c	Rs. 2569/-



**PSN** College of Engineering and Technology  
An Autonomous Institution, Affiliated to Anna University  
Approved by AICTE, Accredited by NAAC with A+ Grade

# LIBRARY MAINTENANCE

**PRINCIPAL**  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYODU, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.





# PSN College of Engineering and Technology

An Autonomous Institution, Affiliated to Anna University  
Approved by AICTE, Accredited by NAAC with A+ Grade

S.No.	DATE	NAME OF THE EQUIPMENT	SUPPLIED BY	QUANTITY	PURCHASED AND MAINTENANCE CHARTER				
					TYPE OF PURCHASE	DETAILS OF PURCHASED/ DETAILS OF SERVICE	VALUE	SIGNATURE	PRINCIPAL
01.	24.07.20	Standard Education Report	Shanthi Books Palayamkottai	44	—	—	1700.00	W.M.	✓
02.	25.07.20	Printer	Regal Star Printstar Technologies Palayamkottai	01	Purchasing the toner cartridge in the LaserJet 1020	—	300.00	W.M.	✓
03.	25	Colour Print	CC Maxx	07	Change Report for G.Martin	—	70.00	W.M.	✓
04.	26	Blue Silver Gold cold and normal water dispensers	01	Purchased	—	1,160.00	W.M.	✓	✓
05.	26	Exide 12V/26Ah Best Voltage Stabilizer System	Accumax Power Systems	01	Purchased	—	6,200.00	W.M.	✓
06.	26/07/20	Service charge for repair & maintenance of online train (Rapid rail) software online of E.Library	**	1	Service	—	4,000.00	W.M.	✓
07.	26/07/20	Gears	Purchased	05	Purchased	—	775.00	W.M.	✓
08.	27.07.20	Electrical materials	Purchased	10	From...Vidwan	—	491.00	W.M.	✓

W.M.  
**PRINCIPAL**  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIOOR, PALAYAMKOTTAI TALUK  
TIRUNELVELI DIST - 627 192



# **SEWAGE TREATMENT PLANT MAINTENANCE**

**PRINCIPAL**  
PSN COLLEGE OF ENGINEERING & TECHNOLOGY  
MELATHEDIYOD, PALAYANKOTTAI TALUK  
TIRUNELVELI DIST. - 627 152.



PSNCFT

# STP Monthly Statement - July 2022

Month  
Year  
8  
Year

Raw effluent  
Transfer  
Two Pumps  
Running  
Hours

AIR Blower  
Two Pumps  
Running  
Hours

Filter Feed  
Two Pumps  
Running  
Hours

Filter Back  
wash  
Running  
Hours

Total  
Sodium  
HYPOCHLORITE  
USE  
(IN KGS)

Other  
Chemicals

PROFESSIONAL  
LEGION OF ENGINEERING & TECHNOLOGY  
KILAKATHEDDOR, PALAYAMKOTTAI - 627 152

Month Year 8 Year	Raw effluent Transfer Two Pumps Running Hours	AIR Blower Two Pumps Running Hours	Filter Feed Two Pumps Running Hours	Filter Back wash Running Hours	Total Sodium HYPOCHLORITE USE (IN KGS)	Other Chemicals
01.07.22 31.07.22	0245 Hours	0438 Hours	0388 Hours	013.30 Hours	013.30 Kgs	080 Kgs
01.08.22 30.08.22	0235 hours	0416 hours	0416 hours	010.80 hours	035 Kgs	046 Kgs
01.09.22 30.09.22	0230 hours	028 Hours	0378 Kgs	011.30 hours	01014 Hours	70 Kgs
01.10.22 31.10.22	0220 Hours	0380 hours	0365 hours	010 hours	0275 hours	65 Kgs
01.11.22 30.11.22	0275 hours	0408 hours	0375 Kgs	011.5 hours	01110.5 hours	58 Kgs
01.12.22 31.12.22	0260 hours	0416 hours	0406 hours	013 hours	01095 hours	48 Kgs

**PSN PG EC and PTC STP PLANT - PSNCET** Water usage Record.

Date	STP Final Water using Timing ON	STP Final Water using Timing OFF	STP Final Water meter Reading Hours Total Hours	STP Final Water Liters	STP Final Water Total Liters	STP Plant In-charge
01.07.22 3.1.07.22	32.5 Hours	64.5 Hours	36 Hours	28,86,000 liters	28,86,000 liters	Jay
01.08.22 3.1.08.22	70. Hours	72. Hours	96 Hours	49,20,000 liters	49,20,000 liters	Jay
01.09.22 3.1.09.22	51.5 Hours	60 Hours	82.30 Hours	660000 liters	660000 liters	Jay
01.10.22 3.1.10.22	59.5 Hours	59. Hours	117 Hours	30,80,000 liters	30,80,000 liters	Jay
01.11.22 3.0.11.22	30. Hours	61.5 Hour	81. Hour	66,80,000 liters	66,80,000 liters	Jay
01.12.22 3.1.12.22	51. Hours	64. Hours	85.0 Hours	68,40,000 liters	68,40,000 liters	Jay

PSNCET COLLEGE OF ENGINEERING & TECHNOLOGY

MELATHEDIVOR, PALAYAKKOTTAI TALUK,  
TIRUNELVELI DIST. - 627 152.

~~PRINCIPAL~~

G. RAMESH  
PROFESSOR  
N. RAMANJANAPPA  
N. RAMADEV  
PSNCET  
E 11/12/22



## **DEPARTMENT LAB MAINTENANCE REGISTER**

	11	23/12/19	Torsion Testing m/c	Technician	01	preventive		
12	24/01/20	Rockwell Hardness Testing m/c	Technician	01	Routine	Cleaning	✓	Thrift
13	24/09/21	UTM	Technician	01	Routine	Oiling & Greasing	✓	Tenz
14	28/09/21	Spring Testing Machine	Technician	01	Routine	Cleaning	✓	Tenz
15	4/10/21	Brinell Hard ness Testing m/c	Technician	01	Preventive	Ball inter denter changing	✓	Tenz
16	25/11/21	Shore D' Hardness Tester	Technician	01	Routine	Cleaning	✓	Tenz
17	5/1/22	Torsion Testing m/c	Technician	01	Routine	Cleaning	✓	Tenz
18	16/7/22	Torsion Testing m/c (SK Testing Instrument)	Technician	01	Preventive	Load Gauge Weeds Assembly Service	3000/-	-

Sl.no	Date	Name of Serviced Equipment [Company name]	Qty	Name of Maintenance Done	Detail of Parts Replaced	Value	Remarks	Staff In-charge
22	27/06/22 To 30/06/22	Lathe	Painter	06	Painting work	6000/-	✓	A.
23	1/7/22	Radial drilling m/c	Painter	01	Painting work	1000/-	✓	A.
24	2/7/22 To 8/7/22	Power Hack saw m/c	Painter	01	Painting work	1000/-	✓	A.
25	2/7/22 To 8/7/22	Electrician	Painter	01	Painting work	1000/-	✓	A.
26	22/07/22 To 12/08/22	Electrical Service by R.D. & Sons (Sriter, 3 core wire, Switches, P.T., etc.)	Electrician	01	Electrical work	74,000/-	✓	A.
27	21.07.22 To 27.07.22	P.G. & P.M. Electrical Services Mr. Arun	Electrician	01	Repairing Lathe who had stoped due to over loading	7800/-	✓	A.
28.	26.07.22 27.07.22 (2nd mtg)	P.G. & P.M. Electrical Services Mr. Arun	1 labour	Rent room in Hall & Borar in flat area	3500/-	✓	A.	A.

11	23/12/19	Torsion Testing m/c	Technician	01	preventive	✓	Swey
12	24/01/20	Rockwell Hardness Testing m/c	Technician	01	Routine	✓	Thrift
13	24/09/21	UTM	Technician	01	Routine	✓	Thrift
14	28/09/21	Spring Testing Machine	Technician	01	Oiling & Greasing	✓	Thrift
15	4/10/21	Brinell Hard ness Testing m/c	Technician	01	Preventive cleaning	✓	Thrift
16	25/11/21	Shore D' Hardness Tester	Technician	01	Routine	✓	Thrift
17	5/1/22	Torsion Testing m/c	Technician	01	Routine	✓	Thrift
18	16/7/22	Torsion Testing (SK Testing Instruments)	Technician	01	Preventive cleaning	✓	Thrift
		Load Gauge Needs Assembly Service	3000/-	-			

D.S.N College of Engineering and Technology

Department of Electrical and Electronics Engineering

17

S No	Date	Name of the Equipment	Serviced by	Auty	Maintenance Done	Nature of Details of part replaced / Details of Services	Value (Rs)	Remark	Staff Incharge	HOD Sign
78	22/7/2022	Crompton brown Fan	J.S.R Electrical and Plumbing	2	-	New crompton fan replaced	3700.00	Cred	Mr. Murali	
79	28/7/2022	LED tube light set	J.S.R.Electrical and plumbing	2	-	New LED tube light set has been replaced	3300.00	Cred	Mr. Murali	
80	28/7/2022	100 Sq. wire coil and plumbing	J.S.R Electrical and plumbing	2	-	New 100 Sq. wire has been replaced	930.00	Cred	Mr. Murali	
81	23/07/2022	Highland Sheet	J.S.R.Electrical and plumbing	3	-	New high land sheet	90.00	Cred	Mr. Murali	
		8x4		1	-		120.00	Cred		
		8x6		1	-		100.00	Cred	Mr. Murali	
		10x8		20	-		100.00	Cred		
		14x4		8	-		216.00	Cred		
		6x4								
82	23/07/2022	1 1/4" Casing Patti and plumbing	J.S.R.Electrical and plumbing	8	-	New casing patti replaced	680.00	Cred	Mr. Murali	
83	23/07/2022	LED Tube light	J.S.R.Electrical and plumbing	4	-	New LED tube light replaced	660.00	Cred	Mr. Murali	
84	23/07/2022	Switch box	J.S.R.Electrical and plumbing	120	-	New Switch box replaced	151.00	Cred	Mr. Murali	
		30x6					120.00	Cred		
		25x6								
85	27/07/2022	Service charges for Quantum power Systems	1	-	online UPS problem has been replaced	6800	Cred	Mr. Murali		
		Repair and Maintenance of online UPS.								
		(Repair of numeric online ups(Panasonic 6800))								
86	12/06/2023	Senior hall windows Repair	Standan and Team	5	-	New window glass cone fixed	17,875	Cred	Mr. Murali	

3 No	Date	Name of the Equipment	Serviced by	July
87	21/6/23	PCs CPU	Agni Computer	4
88	15/7/23	Toner Refilling	Royal Star printer	2
89	26/9/23	Electrical Mechanist Power Electronics Lab Service	NSD Enterprise	II

Details of Part replaced / Details of gorrilla

Nature of Fault	Value (Rs.)	Remarks	Staff Incharge sign	HOD sign
-	10,975	good	P. V. S. (Signature)	21/6/23
Now PC are Repaired				
1. Hard disk - 2 nos - 1.2 2. Cabinet 'CocoNut' - 1 nos - 1 3. Mother board - 1 nos - 2				
-				
Now Toner Refill is good	600	good	P. V. S. (Signature)	15/7/23
Service.				
1. SCR TRIAC & IGBT Trainer 2. VI characteristic of DIAC TRIAC 3. SCR characteristic Trainer. 4. DIAC & TRIAC characteristic Trainer 5. MOSFET & IGBT characteristic Trainer 6. Transient characteristic Trainer 7. 1 ph fully controlled bridge rectifier 8. 3 ph Alternator 9. DC Compound Generation 10. DC Series Motor 11. 3 ph Synchronous Motor & Drive		Good. P. V. S. (Signature) 26/9/23		
All Equipments are Serviced				

27. 8/6/22. Submersible Pump. Self

01

Suckmen Suckmen  
Delivery Delivery  
Ball valve Ball valve  
Complaint P.Gauge  
P.Gauge Hosing  
mounting Mounting  
Replaced Replaced

1340/-

8/11/22  
Indust oil - 80-10

(New O-ring)

Haw

01

Pump Replacement  
Foot of float valve  
Value of float valve  
complaint

300/-

R.R.D.

28. 9/6/22. Self priming pump

(Replaced)

01

Self

100/-

01

Pump Problem Troubleshoot  
and Rounding

3600/-

R.R.D.

29. 16/6/22. Venturimeter

(Replaced)

01

Self

100/-

Pump Problem Troubleshoot  
and Rounding

3600/-

R.R.D.

30. 16/6/22. Diesel Engine Test

(Replaced)

01

Self

100/-

Nozzle Nozzle  
complaint Leaking Anode 3250/-

300/-

R.R.D.

31. 5/7/22. Pelton Turbine

(Replaced)

01

Self

100/-

Crack Valve Crack Valve  
problem. Renewed

200/-

R.R.D.

32. 5/7/22. Venturimeter setup

(Replaced)

01

Self

100/-

Value Value  
complaint Replaced.  
and serviced

500/-

R.R.D.

33. 12/7/22. Venturimeter Setup

(Replaced)

01

Self

100/-

Value Value  
complaint Replaced.  
and serviced

500/-

R.R.D.

34. 12/7/22. Venturimeter Setup

(Replaced)

01

Self

100/-

Value Value  
complaint Replaced.  
and serviced

500/-

R.R.D.

34.	23/7/22	LED Tube light set	JSR Electrical works	50 sets.	Tube light work replacement. is in progress.	7750/-	<u>Mr</u>
35.	27/7/22	Tank work for Fluid Mechanics lab	Mr. Maini carpenter	03	2 collecting tank + Aircraft leg Support	1,200/-	<u>Mr</u>
	18/8/22	Draw Cockpit Friction Loss Diagram		01			
35	11/11/22	FMM lab report.	Self	02	Flexible hose Drain cock	500/-	<u>Mr</u>
36	11/11/22	Meta-Centric height	Mr. Suresh welder.	1	Running welding & waterproof coating & painting tank	1,500/-	<u>Mr</u>
37	17.11.22	borrow from praveen do	Self	01	Leppon	300	<u>Mr</u>
38	11-11-22	Meta centre height	Self	11	Painting work	39.00/-	<u>Mr</u>
39	11/11/22	DPDOL Engine loop	Self	01	ceiling fan Condensor	160	<u>Mr</u>
39.	12.11.22	Ceiling fan	Sri balaji stores	4	ceiling fan & changing		<u>Mr</u>
40	12.11.22	Switch board	Electrician	1	Class room Switch board changes	318	<u>Mr</u>
		Diesel	Indian oil	10lit	Thermal Lab	1000	<u>Mr</u>
41	13.11.22	gas burner & carb	800/-	81	gas burner		<u>Mr</u>
42	13/11/22	Engine oil. 20-40	Viram agency	400ml	Miscosity -Thermal lab	260	<u>Mr</u>
43	8-3-2023	HP Laser MFP B	Unique tech -	Clip -1	Repair, Servic - Clip Change	750	<u>Mr</u>

45.	10.10.23	Reciprocating pump	self	1	Cleaning & Repair the pump inserted		Equipment cleaned	With [initials]
46.	18.10.23	4 stroke diesel engine	Mercury Lab Apparatus - Madurai	1	engine maintenance	1,000	Equipment started	DL (10/10/23)
46.	18.10.23	Diesel engine	Mercury Lab Apparatus - Madurai	1	Cable and plug	140	Equipment started	DL (10/10/23)
47.	18.10.23	Natural & forced convection	Mercury Lab Apparatus - Madurai	1	Rewiring and Service work	1,500	Equipment started	DL (10/10/23)
48.	18.10.23 (18.10.23)	Emulsivity Apparatus	Mercury Lab Apparatus - Madurai	1	Replacement of 12CH selection switch setup, Sensor & Service charge	3,200	Equipment started	DL (18.10.23)
49.	19.10.23	Refrigeration test using Pig refilling	Mercury Lab Apparatus - Madurai	1	Replacement of temperate control unit, sensor, control valve, gas refilling & service charge	11,500	Equipment started	DL (19.10.23)
50.	19.10.23	Air condition Test using Rfg	Mercury Lab Apparatus - Madurai	1	Replacement of temperate control unit, sensor, gas refilling & service charge	6,600	Equipment started	DL (19.10.23)
51.	19.10.23	Boat wash	Mercury Lab Apparatus - Madurai	1	Gas refilling & service charge	5,200	Equipment started	DL (19.10.23)

51. 19.10.23

Rotometer

Thomas electrical

Shop - sivanthipuram

Rs. 500. Pump  
riders

Repaired  
riders

Rs. 12100

52. 19.10.23.

Reciprocating pump

Via ~~mano~~ ~~tan~~ ~~tan~~

Pump maintenance.  
valve & filter replaced

2500

Pump  
repaired

Rs. 1900

52. 19.10.23

calibration

~~by~~

~~venturi~~

~~booster~~

~~orifice meter~~

Thomas electrical  
Shop - sivanthipuram.

valve, pump replaced  
valve & filter replaced  
valve & filter replaced

Rs. 6450

pump  
repaired

Rs. 1900

52. 19.10.23

Europa ~~valves~~ ~~valves~~  
valves

valves

valves made

Rs. 2500

S. No	Date	Name of the equipment / a component	Quantity / System no.	Name of the service by	Details of the parts replacements	Value	Revenue Stmt and HOD sign
1	3 - 8 - 22	Intel Intelligent lab /cpu's	30	arranging the lab system	range working day - 6 - 10.00	10	for 
2	5 - 8 - 22	Intel Intelligent System lab /cpu	15	Software installed (Turbo c)	range working day - 6 - 10.00	10	for 
3	16 - 8 - 22	Intel Intelligent System lab /network cable	15	Networking problem	range working day - 6 - 10.00	10	for 
4.	19 - 8 - 22	Intel Intelligent System lab /cpu's	10	Software installed in Arduino	range working day - 6 - 10.00	10	for 
5	25 - 8 - 22	Intel Intelligent System lab /cpu's	4	Trouble shooting of the CPU problem	range working day - 6 - 10.00	10	for 
6	30 - 8 - 22	Intel Intelligent System lab /pc	2	AC working it Room cleaning	range working day - 6 - 10.00	10	for 
7	3 - 9 - 22	Intel Intelligent System lab /cpu	4	OS installed working	range working day - 6 - 10.00	10	for 

S.No	Date	Name of the service equipment by Company	Quantity system no	Name of the maintenance part replaces	Name of the Value remains staff HOD include sign
8	8-9-22	Intel Intelligent Lab/cable system admin for Network,	3	Cable connected problem on monitor	CPU will be connected the cable monitor working it
9	14-9-22	Intel Intelligent System Lab/Keyboard and mouse, admin and mouse, - not working	2	Replace the keyboard and mouse	- for check
10	21-9-22	Intel Intelligent System Lab /pc admin	2	AC is working it Room cleaning	- for check
11.	29-9-22	Intel Intelligent System Lab/ network cable and Jack, admin	5	Network issued	IP address changed network working it
12	6-10-22	Intel Intelligent System Lab/cpu admin	3	Trouble shooting of the CPU	The RAM will be clearing and working it
13	14-10-22	Intel Intelligent System Lab/cpu admin	1	OS installed	System is working
		Electrican	1	Ac is not working (input power supply is not on)	Ac is working it

Sc. No	Date	Name of the equipment	Name of the service by company	Quantity / system no.	Name of the parts replaces	Value	Remarks	Staff sign	HOD sign
14	28-10-22	Intel Intelligent System Lab	admin and lab/cpus	1	1. Admin working 2. Ram working 3. Hard disk AC is working 4. Monitor working	1500	-		
15	4-11-22	Intel Intelligent System Lab	admin	1	1. Admin working 2. Ram working 3. Hard disk AC is working 4. Monitor working	1500	-		
16	16-11-22	Intel Intelligent System Lab/cpus	admin	1	1. Admin working 2. Ram working 3. Hard disk AC is working 4. Monitor working	1500	-		
17	24-11-22	Intel Intelligent System Lab/cpus	admin	1	1. Admin working 2. Ram working 3. Hard disk AC is working 4. Monitor working	1500	-		
18	9-12-22	Intel Intelligent System Lab/cpus	admin	1	1. Admin working 2. Ram working 3. Hard disk AC is working 4. Monitor working	1500	-		
19	28-12-22	Intel Intelligent System Lab/cpus	admin	1	1. Admin working 2. Ram working 3. Hard disk AC is working 4. Monitor working	1500	-		
		Room Cleaning							
		4. In case of shooting the CPU							

S/N	Name of the equipment / system no.	Quantity / Name of the parts replaces	Name of the main function	Value remains	Parts replaced	HOD sign
20	4-1-23 Intel : Intelligence Lab / Cpus	15 System admin	Table software installed	-	f	f
21	11-1-23 Intel : Intelligence Lab / Cpu	2 System admin	System es installed	-	f	f
22	23-1-23 Intel : Intelligence Lab / Ac	5 System admin	System es working	-	f	f
23	27-1-23 Intel : Intelligence Lab / Ac	6 System admin	System es working	-	f	f
24	2-2-23 Intel : Intelligence Lab / Admin	15 System admin	System es working	-	f	f
25	3-2-23 Intel : Intelligence Lab / Admin	2 System admin	System es working	-	f	f
26	4-2-23 Intel : Intelligence Lab / Admin	2 System admin	System es working	-	f	f
27	5-2-23 Intel : Intelligence Lab / Admin	2 System admin	System es working	-	f	f

Name of the service by has equipment company	Name of the name of the System No.	Value	Revenues incharge sign	HOD sign
26 9-2-23 Intel intelligent system lab/ Network cable	4 Network issued	IP address charged network is working it	T	
27 14-2-23 Intel intelligent system lab/ Network cable	15 Ram issues	AC working it	T	
28 24-2-23 Intel intelligent system lab/ Network cable	2 numbers of displayed issues do played the RAM and cleaning	AC is working installed	T	
29. 2-3-23 Intel intelligent system lab/cpus	5 System admin	The RAM will be clearing and working it	T	
30. 11-3-23 Intel intelligent system lab/ [Electrician]	1 AC	AC is not working (input power supply is not on)	T	
31 18-3-23 Intel intelligent system lab/ admin	2 Ram issues	AC number of displayed issues check the RAM and cleaning	T	

No	Date	Name of the equipment	Service by Company	Quantity /	Name of the system No.	Name of the maintenance	Name of the parts replaced	Value	Remarks	HOD
									Under sign	Sign
29	28-3-23	Intel Intelligent System	Lab/Jack	1	admin	arranging the network system	Jack, lan cable	80	Jack, 2 meter cable	88
33	7-4-23	Intel Intelligent System	Lab/Jack, CPU's Network	1	admin	arranging the network system	Jack, lan cable	15	15 number of Jacks	15
34	19-4-23	Intel Intelligent System	Lab/CPU's	1	admin	arranging the network system	Jack, lan cable	15	15 number of Jacks	15
25	27-4-23	Intel Intelligent System	Lab/CPU's	1	admin	arranging the network system	Jack, lan cable	15	15 number of Jacks	15
36	10-5-23	Intel Intelligent System	Lab/Network	1	admin	arranging the network system	Jack, lan cable	15	15 number of Jacks	15
37	19-5-23	Intel Intelligent System	Lab/CPU's	1	admin	arranging the network system	Jack, lan cable	10	10 number of Jacks	10
28	26-5-23	Intel Intelligent System	Lab/CPU's	1	admin	arranging the network system	Jack, lan cable	5	5 number of Jacks	5

Order No	Date	Name of the equipment	Service by company	Quantity	Name of the parts replaced	Value	Warranty	Staff	HOD
39	8-6-23	Intel Intelligent system	Lab/ admin	15	Cleaning the chassis and monitor	1000	3 months	-	818m
40	14-6-23	Intel Intelligent system	Lab/ network admin	1	Cleaning the chassis and monitor	1000	3 months	-	818m
41	8-6-23	Intel Intelligent system	Lab/ PC admin	1	Cleaning the network cables, track, base, keyboard and monitor	1000	3 months	-	818m
42	11-7-23	Intel Intelligent system	System admin	1	The table of the CPU working	1000	3 months	-	818m
43	19/7/23	Intel Intelligent system	Lab/ Ram.	4	RAM cleaning and system reboot.	1000	3 months	-	818m

S.No	Date	Name of the Service by Lab/ equipments	Name of the Service by Company	Quality Maintenance	Name of the parts Replace	Value Charged	Remarks	Signature	STB Sign	HOD Sign
44	23/4/23	Intel Shuttle Lab/ware	System admin	2.	System admin	0.5	will be updated	✓	✓	✓
45	9/5/23	Intel Shuttle Lab/ware	System admin	Over 4 The system is not working but it is working	Trunkle shooting disk cleaning and working	Ram and Hard disk cleaning and working	✓	✓	✓	✓
46	17/5/23	Intel Shuttle Lab/ware	System admin	15	System Assembly and Cleaning	Van Power cable checked Working	✓	✓	✓	✓
47	30/5/23	Intel Shuttle Lab/ Network admin	System admin	4.	Network Issue	IP Address change and working at	✓	✓	✓	✓



S.NO	Date	Name of service (Quantity) the equipment by company	System No Lab	Name of the Maintenance	Name of the part replaces	Value	Remarks	Lab	HOD
								Asst. sign	Sign
21	14-12-22	IT Lab [Cabin 384] CPU	System admin	44	Java program installed	-	-	-	80
22	15-12-22	IT Lab [Cabin 181] CPU	System admin	9 [77, 74, 81, 72, 93, 31, 13, 18, 53]	Trouble shooting of CPU	The RAM will be cleaning and working fine	-	-	80
23	16-12-22	IT Lab [Cabin 104] CPU	System admin	8 (100, 96, 95 81, 66, 68, 55, 41)	Trouble shooting of CPU	The RAM will be cleaning and working fine	-	-	80 <i>W.D.</i>
24	17-12-22	IT Lab [Cabin 104] CPU	System admin	8 (98, 97, 94 53, 50, 18, 66, 68) (8)	Trouble shooting of CPU <i>8</i> cleaning the systems	The RAM will be cleaning and working fine	-	-	80
25	19-12-22	IT Lab [Cabin 104] admin	System admin	2 (16, 45) 4 (50, 18, 55, 68, 79, 96)	OS installed (8) Trouble shooting of CPU	System is working (8) The RAM will be cleaning and working fine	-	-	80

S.No	Date	Name of the equipment by company	Quantity	Name of the System No	Name of the Maintainer	Name of the parts replaces	Value	Remarks	L.A sign	H.O.D sign
26	20-12-22	IT Lab [cabin 1 to 4] system admin CPU	10	(1, 13, 18, 33, 40, 42, 59, 62, 69, 95)	Trouble shooting of CPU	The RAM will be cleaning and working fine	-	-	800	
			3	(16, 67, 89)	start up problems	The system is rebooting is not working.	-	-	500	
27	21-12-22	IT Lab [cabin 1 to 4] system admin CPU	33	Weka software installed	-	-	-	-	500	✓
			8	(12, 18, 49, 52, 60, 64, 92, 74)	Trouble shooting of CPU	The RAM will be cleaning and working fine	-	-	800	
28	22-12-22	IT Lab [cabin 1 to 4] system admin CPU	10	(13, 17, 32, 34, 47, 63, 64, 74, 92, 81)	Trouble shooting of CPU	The RAM will be cleaning and working fine	-	-	800	
			2	(1, 59)	cable connected problem on monitor	CPU will be connected the cable monitor working it	-	-	800	
29	23-12-22	IT Lab [cabin 1 to 4] system admin CPU	8	(1, 18, 53, 51, 38, 63, 78, 79)	Trouble shooting of CPU	The RAM will be cleaning and working fine	-	-	800	
			1		system cleaning	-	-	-		

SNO	Date	Name of Service by the equipment Company	Quantity/ System no	Name of the Maintenance	Name of the parts Replaces	Value	Remarks L.A	HOD Sign	Sign
30	26-12-22	IT Lab system [Cabin 1 to 4] admin	18 (18, 3), 34, 38, 45, 56, 59, 63, 70, 79, 81, 84)	Trouble shooting of the CPU	The RAM will be cleaning and working fine	-	-	-	-
		Camera		camera are checking	camera are working	-	-	Door	
31	27-12-22	IT Lab system [Cabin 1 to 4] admin	9 (31, 33, 47, 56, 58, 84, 86, 94, 95).	Trouble shooting of the Epo	The RAM will be cleaning and working fine	-	-	-	Door ✓
			2	AC is not working (input power supply is not on)	-	-	-	-	
32	28-12-22	IT Lab system [Cabin 1 to 4] admin	11 (11, 13, 24 31, 38, 33, 45, 56, 55, 61, 62),	Trouble shooting of the CPU	The RAM will be cleaning and working it	-	-	-	Door
			[Cabin 1, 2]	Weka soft ware ( 42 installed	-	-	-	-	

S.NO	Date	Name of Service by (Quantity) the equipment company	Name of System No lab /	Name of the Maintenance	Name of the Value remarks 1 A part replaces	HOD Sign	Sign
37	4-1-23	IT Lab System	12	Trouble shooting (1, 18, 19 of the CPU 31, 38, 51, CPU 53, 59, 75, 87, 95, 97)	The RAM will be cleaning and working it	<i>See</i>	<i>Patip</i>
38	6-1-23	IT Lab System	15	Trouble shooting (1, 24, 32, of the CPU 53, 47, 56, 74, 78, 81, 83 87, 94, 95, 97, 100)	The RAM will be cleaning and working it	<i>See</i>	
39	9-1-23	IT Lab System	12	Trouble shooting (13, 24, of the CPU 32, 33, 56, 59, 66, 69, 70, 81, 97)	IP address changed is working it	<i>See</i>	
40	11-1-23	IT Lab System	12	Trouble shooting (9, 13, 18 of the CPU 43, 56, 66 70, 72, 83, 84, 95, 97)	The RAM will be cleaning and working fine	<i>See</i>	

S.NO	Date	Name of the equipment/company	Service Quantity	System No	Name of the Maintenance	Name of the part replaces	Value	Remarks	L.A	H.O.D
78	3-5-23	IT Lab	System admin	[cabin 1 to 4]	System cleaning	-	-	-	-	Sign
		Ram,	6	(74, 81, 82, 93, 95, 99)	Trouble shooting of the CPU	The RAM will be Cleaning and working it	-	-	See Chkd	05/05/23
79	16-5-23	IT Lab	System admin	[cabin 1 to 4]	4	A/C working it	-	-	-	See Chkd
		CPU, Ram	8	(22, 34, 45, 56, 79, 84, 93, 96)	Trouble shooting of the CPU	The RAM will be Cleaning and working it	-	-	See Chkd	05/05/23
80	18-5-23	IT Lab	System admin	[cabin 1 to 4]	UPS water cooled	-	-	-	-	See Chkd
		UPS, distilled water,	4	(56, 77, 80, 94)	Trouble shooting of the CPU	The RAM will be Cleaning and working it	-	-	-	See Chkd
		cabin 3 CPU's	7	Jalla 3-8-7	Software installed	-	-	-	-	See Chkd
81	20-5-23	IT Lab	System admin	[cabin 1 to 4]	Room cleaning & system cleaning	-	-	-	-	See Chkd

Sr.no	Date	Name of the Service	Quantity	the equipment by company	System No	Name of the Maintenance	Name of the part replaces	Value	Remarks	L.A	H.O.D	Sign	Sign
-------	------	---------------------	----------	--------------------------	-----------	-------------------------	---------------------------	-------	---------	-----	-------	------	------

82 22-5-23 IT Lab System 1  
 [cabin 1 to 4] admin 4 camera checking it - - -  
 AC cabin 2 8 4 AC working it - - -  
 Java 3.8.7 software installed - - -

83 25-5-23 IT Lab System 6  
 [cabin 1 to 7] admin (81, 85, 93) Troubleshooting The RAM will be  
 CPU's 99, 74, 22) of the CPU cleaning and worry  
 it  
 Distilled water UPS water level  
 water checking it - - -

84 29-5-23 IT Lab System 1 Python 3.8.7 installed System is working  
 [cabin 1 to 7] admin it - - -  
 CPU's python 3.8.7 installed - - -  
 [Cabin 3 & 4] system 3.6 installed - - -

85 2.6-23 IT Lab System 15 python 3.8.7 installed - - -  
 [cabin 1 to 7] admin Network issued IP address changed  
 CPU's - - - network is working it  
 Notebook cable system cleaning - - -

s.no	Date	Name of Service the equipment by company	Quantity/ System No Lab.	Name of the Maintenance	Name of the part replaces	Value remarks, L.A sign	HOD sign
90	19-6-23	IT Lab System [Cabin 104] admin	5 CPU	Network issued	IP address changed network is working it	- -	- -
			6 CPU	Trouble shooting (32, 48, 61 of the CPU 74, 85, 86)	The RAM will be cleaning and working it	- -	- -
91	21-6-23	IT Lab System [Cabin 104] admin	5 CPU	(81, 83, 93, 94, 95) of the CPU	The RAM will be cleaning and working it	- -	- -
			1	AC working it	- -	- -	- -
92	24-6-23	IT Lab System [Cabin 104] admin Ram, EPS,	1 4	System cleaning Room cleaning camera working it UPS water level checkbox it	- - - - - - fill the water in 4 battery	- -	- -
93	27-6-23	IT Lab System [Cabin 104] admin	6 CPU	6 (48, 56, 81, 93, 97, 95) Argocml software installed	The RAM will be cleaning and working it	- -	- -

Sl No	Date	Name of the Lab/ equipments	Service by Company a company	Quantity	Name of the maintenance done	Details of the parts replaced	Value	Remarks	Start Date Sign	HOD Sign
1.	3.8.22	Project Lab / cpus and Monitors	System admin	-	arranging the lab system	-	10000/-	-	3.8.22	✓
2.	5.8.22	Project Lab / cpus	System admin	10	software	-	10000/-	-	5.8.22	✓
3.	13.8.22	Project Lab / Networks Cables, and Jacks	System admin	arranging the Networks system, Cimmed 15 no. of system	arranging the Network system Cimmed 15 no. of system	Jacks, Lan cable 30 Jack, 2 Metre LAN cable (lan)	10000/-	-	13.8.22	✓
4.	26.8.22	Project Lab / computers	System admin	15 Number.	Installed the Visual studio Professional 2010 on Project lab	metodk software installed.	metodk software installed.	-	26.8.22	✓
5.	7.9.22	Project Lab / CPUS Software Installed.	System admin	15 Number.	Check the Software with Programming Install the Python Programming Software for a	metodk software installed.	metodk software installed.	-	7.9.22	✓
6.	23.9.22	Project Lab / computer	System admin	2 Number.	trouble shooting at 2 numbers of System. 10 PC's are checked and the Network (Intet net) is provided.	metodk trouble shooting	metodk trouble shooting	-	23.9.22	✓
7.	8.10.22	Project Lab / cpus Network Jack, Cables,	System admin	18-	18 PC's are checked and the Network (Intet net) is provided.	metodk network checked	metodk network checked	-	8.10.22	✓
8.	17.10.22	Project Lab /	System admin	1	PC Numbers are displayed issues, check the Ram and cleaning.	metodk Ram checked	metodk Ram checked	-	17.10.22	✓

16	03-10-93	project	system	adrun	lab	CPUs	and memory
15	03-10-93	project	system	adrun	lab	CPUs	and memory
14	16-10-93	project	system	adrun	lab	CPUs	and memory
13	9-10-93	project	system	adrun	lab	CPUs	and memory
12	9-11-93	project	system	adrun	lab	CPUs	and memory
11	16-11-93	project	system	adrun	lab	CPUs	and memory
10	03-11-93	project	system	adrun	lab	CPUs	and memory
9	03-12-93	project	system	adrun	lab	CPUs	and memory
8	15-11-93	project	system	adrun	lab	CPUs	and memory
7	15-11-93	project	system	adrun	lab	CPUs	and memory
6	15-11-93	project	system	adrun	lab	CPUs	and memory
5	15-11-93	project	system	adrun	lab	CPUs	and memory
4	15-11-93	project	system	adrun	lab	CPUs	and memory
3	15-11-93	project	system	adrun	lab	CPUs	and memory
2	15-11-93	project	system	adrun	lab	CPUs	and memory
1	15-11-93	project	system	adrun	lab	CPUs	and memory



S & NO	Date	Name of the service by equipment lab	Quantity	Name of the system No. company name	Name of the maintenance	Name of the parts replace	Value	Remarks	Staff sign	HOD sign
35.	28-6-23	Project Lab/ CPU's	System admin	System	System cleaning Room cleaning. Projector is working it	-	-	-	Jay p. Chettri	
			3	Trouble shooting of the opb	The RAM will be cleaned and working it	-	-	-	Jay	
36.	17-10-23	Project Lab/ CPU's	Ameer cooler & Infotech J.S.R materials	for fitting Air Conditioner	A/C fitting materials	200/- 92/-			Jay 18/10/23 p. Chettri	
37.	12-12-23	Network Jack/ cable	System admin	2-cpu Jacks /2 cat 6/cable 1 meter.	Network Problem	2 Jack / cat 6 cable one meter.	-	-		
38.	16-3-24	Project Lab/ 2 CPU's	Agni computers	2 -cpu's	2 systems fed to one computer for mainframe.	-	-	-	Jay 16/3/24 p. Chettri	C. T. M
				Intel processor core i9 13 gen.	Specified intel core i9 13 gen.	-	-	-		
				ASUS H61 Mother Board, 8GB DDR3	ASUS H61 Mother Board, 8GB DDR3	-	-	-		
				Ram, Hard disk	Ram, Hard disk 512 GB SSD	-	-	-		